

Appendix D to 2015 CPUC Annual Report

Safety Incidents Open as of 1-1-2015 and Incidents Reported in 2015

Gas Incidents

(In Compliance with CA Public Utilities Code Section 911 & Senate Bill 1409 signed into law on September 25, 2014)

Incident ID: This number reflects the year, month, the day, the sequence the incident is reported/occurred

Incident ID (YYYYMMDD-XX)	Facility Owner	Reason for Investigation	Facility Type	Brief Description of Incident	Open or Closed
20121201-01	PG&E	Damages Above 50K	Transmission	PG&E was notified at 8:40AM of a release of gas at 3205 E Miner Street, Stockton, San Joaquin County. PG&E arrived on-site at 9:05AM and the flow of gas was stopped at 9:56AM. Release of gas caused by pipeline rupture. Approximately 100 customers expected	Open
20130106-01	SoCalGas	Damages Above 50K	Transmission	An overpressurization event caused a gas release from relief valve that ignited at the relief valve vent in the Playa del Rey Underground Storage facility. Fire extinguished and there were no injuries reported. However, clean-up estimates coming in indicate total cost has potential to exceed \$50,000.	Closed
20140114-01	SoCalGas	Media Coverage	Main	A leak was called into the city of Palm Desert. The gas company has responded to control gas and make repairs on a cracked Aldyl-A tee. This incident was reported due to the presence of media. Gas co. is currently on scene doing repairs.	Closed
20140114-02	SoCalGas	Damages Above 50K	Service Line	A 3/4" steel service riser was damaged due to electrical arching that travelled through the grounded line and ignited. The ignition caused damage to a nearby wooden fence and garage estimated to exceed \$50,000.	Closed
20140123-01	SoCalGas	Media Coverage	Regulator	An area odor was called in. The Social Gas representative found a leaking regulator at a regulator station. M&R was dispatched and made permanent repairs. The incident was reported late as Social Gas was initially unaware of media coverage.	Closed
20140214-01	SoCalGas	Media Coverage	Main	The customer at the location called in a gas leak/odor on 2/13/2014. SoCal Gas crews responded and confirmed nonhazardous leak indications in the area of the parkway near the street and notified the customer that it was nonhazardous but would return for the repairs. On 2/14/2014, SoCal Gas found that the customer reported the gas leak to Channel 4 news, and later repaired the code 3 leak. The incident was reported to the CPUC due to media coverage.	Closed
20140218-02	SoCalGas	Media Coverage	Main	A third-party contractor working on street lighting construction hit a 3-inch plastic gas main. This incident became reportable due to media presence.	Closed
20140218-03	PG&E	Media Coverage	Service Line	A third-party excavator struck and damaged a 1" plastic service line causing an unintentional release of gas.	Closed
20140218-04	PG&E	Media Coverage	Main	A third-party dig-in at the intersection of 25th St & Diamond St in San Francisco damaged a 4" plastic main causing an unintentional release of gas. The line struck was a 4" plastic main.	Closed
20140219-01	SoCalGas	Damages Above 50K	Main	High pressure water main break intruded into an 8" steel gas main causing service interruption and estimated property damage cost exceeding \$50,000.	Closed
20140219-02	SoWEST	Damages Above 50K		Southwest Gas notified by customer of "no Gas" and found zero pressure at Needles City Gate due to inadvertent closure of a PG&E valve that supplies Southwest Gas' distribution system.	Closed

20140219-04	PG&E	Media Coverage	Service Line	A third-party excavator struck and damaged a 1/2" plastic gas service line causing an unintentional release of gas.	Closed
20140306-01	PG&E	Media Coverage	Main	A third-party dig-in at Sutter and Jones in San Francisco damaged a 2" plastic gas main causing an unintentional release of gas.	Closed
20140306-02	PG&E	Media Coverage	Service Line	A third-party dig-in damaged a 1/2 copper gas service causing an unintentional release of gas.	Closed
20140306-03	SoCalGas	Media Coverage	Main	Third party excavation damage on 4-inch steel distribution main causing a release of gas.	Closed
20140310-02	SDG&E	Damages Above 50K	Customer Meter	A taxi cab ran over a meter set damaging the assembly and causing a release of gas.	Closed
20140314-01	PG&E	Damages Above 50K	Transmission	PG&E was performing work on L-101 on 3/13/2014 to install a 2-inch Save-A-Valve tee as part of a internal pipeline inspection project. During the tapping and plugging operation, the completion plug began to leak at the threads. Repairs are expected to exceed \$50,000.	Closed
20140324-01	SDG&E	Media Coverage	Service Riser	AN SDG&E employee working on meter for a fumigation order broke valve off riser causing leak. Distribution crew on scene working on gas control. Reported due to Media on scene.	Closed
20140326-01	PG&E	Damages Above 50K	Transmission	PG&E contractor was performing deactivation work on what was believed to be the deactivated transmission line 172A at the corner of Pine and Green Meadow Streets in West Sacramento. Instead, the PG&E contractor inadvertently burned a hole on a parallel 16-inch pressurized transmission pipe causing a release of gas.	Closed
20140407-01	PG&E	Media Coverage	Regulator	A structure fire at 4655 Mossbrook Circle in San Jose, Santa Clara damaged the gas meter set assembly causing a release of gas.	Closed
20140408-01	SoCalGas	Media Coverage	Main	A third-party contractor struck a 2" plastic gas distribution main causing a release of gas.	Closed
20140408-04	PG&E	Media Coverage	Main	A third party contractor working for the City of San Francisco struck a 4-inch plastic distribution main while excavating to install new sewer laterals.	Closed
20140409-02	PG&E	Media Coverage	Service Line	A third party excavator struck and pulled a 1-inch plastic service from an 8-inch steel gas distribution main while working on a sewer line.	Closed
20140425-01	SDG&E	Media Coverage	Main	Public works department dug outside delineated and marked area, and struck 1/2" plastic gas service	Closed
20140430-02	SDG&E	Media Coverage	Service Riser	A landscaper mowed over a gas riser covered with grass causing a leak.	Closed
20140501-01	SoCalGas	Media Coverage	Customer Meter	Fire damaged homes and burned approximately one half acre. As one or more homes burned, burning debris fell on two meterset assemblies which broke the risers. Escaping gas ignited, but did not contribute to property damage or injuries of 3 persons burned from fire.	Closed
20140506-01	SoCalGas	Media Coverage	Service Line	LADWP excavating to install electrical conduit hit a 2" gas service.	Closed
20140507-01	SDG&E	Media Coverage	Main	A third-party contractor struck and damaged a 4" steel gas main while installing communication conduits.	Closed
20140514-01	PG&E	Casualties or Inpatient Hospitalization	Customer Meter	A vehicle traveling at a high rate of speed left the roadway, struck a residence causing significant structural damage and also struck PG&E gas and electric facilities at 405 Rambler Rd., Merced. The event resulted in a fire and a fatality.	Closed
20140515-01	PG&E	Media Coverage	Main	A third party excavator struck a 6-inch plastic distribution main on Summerset Drive in Rio Vista.	Closed
20140522-02	SoCalGas	Gas Loss	Main	A third-party contractor struck 2" plastic gas main.	Closed
20140524-01	PG&E	Operator Judgement	Customer Meter	A structure fire at 760 Sir Francis Drake Blvd in San Anselmo damaged a gas meter manifold causing a release of gas.	Closed

20140529-01	PG&E	Media Coverage	Main	A third-party party dig-in at the intersection of Ruby Avenue and Tully Road in San Jose damaged a 4-inch plastic gas distribution main causing a release of gas.	Closed
20140529-02	PG&E	Interruption	Main	A third-party dig-in of a 4-inch gas distribution main at 10983 N. Wolfe Road, Cupertino (Vallco Village Shopping Center) caused a release of gas. Incident was reported to the CPUC due to the large number of commercial customers affected by the service interruption.	Closed
20140529-03	PG&E	Interruption	Service Line	A third-party dig-in at 1050 Andersen Road in San Rafael damaged a 4-inch plastic gas distribution main. Incident was reported to the CPUC due to the large number of commercial customers affected by the service interruption.	Closed
20140530-01	SDG&E	Media Coverage	Service Line	A third-party excavator struck and damaged a 1/2" plastic gas service during pot holing of the facility.	Closed
20140602-01	SoCalGas	Media Coverage	Service Riser	Debris from roof fell and snapped gas meter bypass during remodel causing a release of gas. Reported due to media presence.	Closed
20140605-01	SoCalGas	Media Coverage	Customer Meter	Explosion, reported to be unrelated to the gas facilities, inside a residential structure pushed a wall into the gas meter knocking it off the meter set assembly.	Closed
20140606-01	SoCalGas	Media Coverage	Customer Meter	A vehicle drove over a parking spot through a grass area and hit the meter set assembly causing a leak.	Closed
20140609-01	PG&E	Media Coverage	Service Line	A third party dig-in at 580 Texas St., Fairfield damaged a 1" plastic gas service resulting in a release of gas.	Closed
20140610-01	SDG&E	Media Coverage	Service Line	A third-party contractor struck and damaged a 1/2" plastic gas service line with a post hole digger. Reported due to media coverage.	Closed
20140611-01	SDG&E	Media Coverage	Service Riser	Police high speed chase ending in vehicle accident damaged the gas meterset assembly at a business location.	Closed
20140611-02	SoCalGas	Media Coverage	Service Riser	A vehicle struck the gas meterset assembly resulting in a gas leak. The incident was reported due to media presence.	Closed
20140611-03	SoCalGas	Gas Loss		Report of gas odor caused by a cracked fitting on a 4" plastic gas fitting. This incident was reported due to media presence.	Closed
20140613-01	PG&E	Damages Above 50K	Customer Meter	Structure fire reported at multiple homes at 1000, 1002, and 1008 Stevens St. in Taft, CA of Kern County damaged gas meter. Property damage estimated to exceed \$50,000.	Closed
20140618-01	PG&E	Media Coverage	Main	A PG&E contractor digin incident occurred at 1640 School Street in Moraga. The contractor struck a 2.5" steel distribution main during saw-cutting activities.	Closed
20140620-01	PG&E	Damages Above 50K	Main	A third-party dig-in occurred near Somersville Road and James Donlon Blvd. in Antioch damaged a 4" plastic distribution main that caused an unintentional release of gas.	Closed
20140620-02	PG&E	Media Coverage	Valve	A brush fire on a vacant lot melted an underground gas service valve at 2117 Cordelia Ave. in Fairfield. The brush fire also led to two structure fires and an electric pole fire.	Closed
20140623-01	SDG&E	Media Coverage	Main	A third-party landscape contractor damaged a 2" plastic main causing a release of gas.	Closed
20140624-01	SoCalGas	Media Coverage	Main	A SoCal Gas crew was excavating to perform maintenance on a valve, a 3/4" fitting was hit by the backhoe causing the leak.	Closed
20140627-01	PG&E	Media Coverage	Customer Meter	A structure fire at 435 Tulip Street in Fairfield damaged the gas meter.	Closed
20140628-01	PG&E	Operator Judgement	Service Riser	A structure fire at 601 West School Street in Cotati damaged the gas meterset causing a release of gas.	Closed
20140701-01	SoCalGas	Media Coverage	Main	A third party contractor dug-in into 3" plastic gas line.	Closed
20140702-01	SoCalGas	Casualties or Inpatient Hospitalization	Service Line	Customer/Homeowner struck 1/2" plastic gas service line with a pick ax while trenching to install electrical conduit. Incident reported to the CPUC when the excavator was taken to the hospital due to eye injury. It was later determined that the injured homeowner was not	Closed

admitted to the hospital.

20140707-01	PG&E	Media Coverage	Customer Meter	A structure fire at 320 Village Lane, Los Gatos damaged the meter set and a release of gas.	Closed
20140707-02	PG&E	Operator Judgement	Customer Meter	A structure fire damaged the meterset assembly causing a release of gas. Incident initially reported as damages may exceed \$50,000.	Closed
20140709-01	SDG&E	Media Coverage	Service Line	A third-party contractor hit and damaged a 1/2" plastic gas service with hand tools.	Closed
20140709-02	PG&E	Media Coverage	Service Line	A third-party installing a fence for a customer at 2849 S. White Rd., San Jose hit and damaged a 1" plastic gas service line resulting in a release of gas.	Closed
20140711-01	SDG&E	Media Coverage	Service Line	A third-party contractor hit a 1 1/4" gas service main with an auger while digging to install temporary power poles causing a leak.	Closed
20140715-01	PG&E	Media Coverage	Main	A PG&E crew struck and damaged a 2" steel gas distribution main with a backhoe while repairing a leak on a service at 242 Arleta Avenue, San Francisco.	Closed
20140718-01	SoCalGas	Damages Above 50K	Transmission	A third-party contractor struck and damaged a 10" steel gas transmission line while grading for a pond. No reported injuries or fatalities. Reported to DOT due to potential that damage could exceed \$50K and/or gas lost could exceed 3 million cubic feet.	Closed
20140718-02	PG&E	Damages Above 50K	Service Riser	A residential fire at 1840 E 23rd Street Unit A, in Merced by the Mariposa Fire Department. The electrical weather head reported fell and damaged the gas meterset assembly causing a release of gas.	Closed
20140719-01	SDG&E	Media Coverage	Customer Meter	This incident was called into the CPUC at 06:23 but did not indicate reporting to DOT. DOT was notified due to injury of passenger of car and is unknown at this time if the individual will be hospitalized based on those injuries. Summary: At or near 4:30a	Closed
20140722-01	PG&E	Media Coverage	Customer Meter	A vehicle accident damaged a gas meter set at 2045 Evans Ave, San Francisco causing a release of gas. The driver of the vehicle was transported to the hospital for injuries sustained from the vehicle impact.	Closed
20140723-01	PG&E	Media Coverage	Main	A third party dig-in at 333 S Capitol Ave, San Jose, CA damaged a 3" plastic gas distribution main near the Santa Clara Valley Transportation Authority Alum Rock light-rail station.	Closed
20140723-02	SoCalGas	Media Coverage	Main	A third-party contractor pulled off a 4" fitting on a gas distribution main causing a release of gas.	Closed
20140728-01	SDG&E	Media Coverage	Service Line	A third-party contractor was digging with a backhoe when they struck the 2" plastic gas main resulting in a gas leak.	Closed
20140729-01	Propane	Operator Judgement	Customer Meter	Ferrel Gas reported this incident to the CPUC on 08/29/2014. An electrical fire at Whispering Pines MHP (Propane CPUCID 1109), space #18, resulted in part of the customer's meter being partially melted.	Closed
20140730-02	SoCalGas	Media Coverage	Service Riser	A vehicle hit the gas meterset assembly resulting in a leak. The incident was reported due to media presence.	Closed
20140804-01	SoCalGas	Media Coverage	Service Line	A third-party contractor was excavating to install electrical when they struck a 1" plastic gas service causing a leak. Incident reported due to media coverage.	Closed
20140804-02	PG&E	Media Coverage	Main	A third-party contractor struck and damaged a 3" plastic gas distribution main at 1975 Diamond Boulevard in Concord.	Closed
20140810-01	SDG&E	Media Coverage	Customer Meter	Homeowner's vehicle struck the meterset assembly causing a release of gas.	Closed
20140811-01	PG&E	Media Coverage	Main	A third-party dug into a 4" plastic distribution main causing a release of gas.	Closed
20140818-01	PG&E	Media Coverage	Service Riser	A structure fire at an abandoned carpet warehouse at 10121 San Leandro Street melted the gas riser causing a release of gas and fire.	Closed

20140819-01	PG&E	Damages Above 50K	Transmission	While excavating over transmission line 173 for pipeline work, PG&E crew struck a 3/4" tee on a transmission line with power equipment causing a release of gas.	Closed
20140820-01	SoCalGas	Media Coverage	Main	A third-party excavation damaged a 2" plastic gas main while installing electrical conduit.	Closed
20140820-02	PG&E	Media Coverage	Main	A third-party excavator struck and damaged a tee off a 4" steel gas distribution main at 9060 Auburn-Folsom Boulevard and Eureka Road in Granite Bay.	Closed
20140822-01	SoCalGas	Media Coverage	Main	A third party contractor was performing work to excavate for a sewer line when they struck a 2" plastic gas main causing a gas leak.	Closed
20140824-01	PG&E	Damages Above 50K	Main	A magnitude 6.0 earthquake struck the Napa County area. PG&E has received and responded to customer odor calls and calls from Fire and Police agencies throughout the morning. PG&E has confirmed and remediated leaks on a number of damaged service risers.	Closed
20140902-01	PG&E	Media Coverage	Customer Meter	A vehicle slammed into the home on 208 Midland Way in Danville damaging the meterset and causing an unintentional release of gas.	Closed
20140902-02	SDG&E	Media Coverage	Service Line	A third-party excavator installing fence posts struck and damaged a 1" plastic service gas line causing a leak.	Closed
20140903-01	PG&E	Media Coverage	Customer Meter	A structure fire occurring at 1905 The Alameda in San Jose damaged the meterset assembly causing a release of gas.	Closed
20140903-02	SDG&E	Media Coverage	Main	A third-party excavator hit and damaged a 2" plastic gas main while installing in a new copper water service.	Closed
20140904-01	PG&E	Media Coverage	Customer Meter	A police pursuit ended in a vehicle crashing into a commercial building at 1320 Petaluma Hill Road in Santa Rosa. The gas meter set and riser was damaged from the vehicle impact, resulting in an unintentional release of natural gas.	Closed
20140905-01	PG&E	Operator Judgement	Main	A third-party struck and damaged a service line saddle on a 3" gas distribution main at the south-west corner of 11th and Camino Real in Carmel by the Sea.	Closed
20140905-02	PG&E	Interruption	Main	A third-party was grading the area when they struck a 4" steel distribution main causing an unintentional release of gas.	Closed
20140905-03	PG&E	Media Coverage	Regulator	An AC transit bus crashed into a home(duplex) at 789 18th St. &1770 Garvin Ave. in Richmond. The Police were chasing a stolen car that collided into the bus, causing the bus to crash into the home, damaging a 2-meter manifold. There were reported injuries due to the vehicle impact.	Closed
20140907-01	SDG&E	Damages Above 50K	Customer Meter	Electric arcing from a gas pipeline tracer wire against the steel riser, as a resulted in a structure fire at a residence in Fallbrook. Unknown cause. Gas under control at approximately 8:00 am. Damage estimated to be greater than \$50,000.	Closed
20140911-01	SDG&E	Media Coverage	Customer Meter	A vehicle struck a meterset assembly causing a leak. Reported due to media coverage	Closed
20140911-02	SoCalGas	Casualties or Inpatient Hospitalization	Service Line	A third-party contractor working for the home owner at 285 Flower Dr., Lake Arrowhead, cut into the gas service riser with a hack saw causing a release of gas. The contractor was taken to the hospital due to gas inhalation but later released.	Closed
20140911-03	SDG&E	Media Coverage	Main	A third-party contractor was digging to install a parking meter when they struck a 2" plastic gas main causing a gas leak	Closed
20140912-01	SDG&E	Media Coverage	Service Line	A third party contractor working for the H.O.A. was excavating and struck a 1" plastic line causing a gas leak. Media is on scene.	Closed
20140915-01	PG&E	Operator Judgement	Customer Meter	A structure fire caused by a down electric line resulted in the house collapsing onto the meterset aseembly causing a release of gas.	Closed
20140915-02	SDG&E	Media Coverage	Other	A third party contractor struck and damaged a 1/2" plastic gas service. This was reported due to media coverage.	Closed
20140915-04	PG&E	Damages Above 50K	Main	A third-party excavator struck and damaged a 2" steel distribution main causing a release of gas. Damages exceed \$50,000.	Closed
20140922-	PG&E	Media	Main	A third-party struck a 3" steel gas distribution main resulting at	Closed

01		Coverage		23185 Maud Avenue in Hayward.	
20140924-01	PG&E	Media Coverage	Service Line	PG&E crew struck a 4-inch main at 4245 W. Ashlan Avenue, Fresno during a scheduled cut off of a gas service from the main.	Closed
20140925-01	PG&E	Operator Judgement	Valve	A structure fire at 4655 King Road in Loomis damaged the meterset assembly causing a release of gas. Damage to the property estimated to exceed \$50,000.	Closed
20140925-02	PG&E	Media Coverage	Main	A report of gas leak at 3939 N. Pershing Avenue, Building A, in Stockton. The source of the leak was determined to be a cracked 4-inch plastic tee on the distribution main, damaged by a tree root from the tree trunk located approximately 25 feet away.	Closed
20140930-01	PG&E	Damages Above 50K	Main	A third-party damaged a 4" steel gas distribution main in San Jose (near the intersection of Ridder Park Drive and Schallenberger Road).	Closed
20141002-01	SDG&E	Media Coverage	Service Line	A third party contractor was excavating and struck a 1/2" plastic service. This was reported due to media coverage.	Closed
20141005-01	PG&E	Casualties or Inpatient Hospitalization	Service Riser	Structure fire at 935 Broadway St. King City. Gas released at meter set has ignited. Three injuries were reported for this incident; two injuries were treated and released on site but one resident received third degree burns that required overnight hospitalization. Damages to the structure exceed \$50K.	Closed
20141006-01	SDG&E	Media Coverage	Main	A third party contractor struck a 2" plastic gas main. This incident was reported due to media coverage.	Closed
20141010-01	PG&E	Operator Judgement	Customer Valve	A structure fire damaged the gas meterset assembly causing a release of gas.	Closed
20141010-02	PG&E	Operator Judgement	Main	Inadvertent closure of a valve resulted in service interruption to multiple gas customers during a gas clearance at Chelsea Avenue and 1st Street in Napa.	Closed
20141011-01	PG&E	Media Coverage	Service Riser	A structure fire at 1695 Blossom Avenue, Fairfield damaged the meterset assembly causing an unintentional release of gas.	Closed
20141013-01	PG&E	Media Coverage	Customer Meter	A vehicle collision with a meter set and service riser at 312 Argonaut Avenue, San Francisco caused an unintentional release of gas.	Closed
20141015-01	PG&E	Media Coverage	Service Line	A third-party struck a 1/2" plastic service line with a snake auger while cleaning out a storm drain at C Street and 12th Street in Sacramento.	Closed
20141015-02	SoCalGas	Damages Above 50K	Valve	SoCal Gas loss service to multiple customers during a gas clearance work when a valve at a regulator station was closed causing the outage.	Closed
20141017-01	PG&E	Media Coverage	Service Riser	An electric arc from a SMUD transformer caused a hole on a 1.25" steel service line at 2275 Benita Drive in Rancho Cordova, California, and released gas to the atmosphere.	Closed
20141019-01	PG&E	Operator Judgement	Customer Meter	A structure fire at South Hazelwood Boulevard and South First Street in Fresno damaged gas meterset assemblies causing a release of gas.	Closed
20141024-01	PG&E	Media Coverage	Transmission	A farmer ripping a field dug into a 34" gas transmission line L-300A at Wible Road and Houghton Road in Bakersfield.	Closed
20141026-01	SoCalGas	Media Coverage	Service Riser	A vehicle struck and damaged a 1" plastic service riser. This was reported due to media coverage.	Closed
20141028-01	SoCalGas	Damages Above 50K	Service Line	A third party contractor excavating to install irrigation system struck a service line. It is believed that the gas leaked through conduits getting into the garage and created the explosion.	Closed
20141029-01	PG&E	Damages Above 50K	Transmission	During a routine leak survey of Transmission Line, a non-hazardous leak was discovered at the casing vent on L-132 at Mile Point 3.07. The 30-inch casing and 24-inch L-132 cross beneath the Union Pacific Rail Road near Lafayette and Gianera.	Closed
20141030-02	PG&E	Media Coverage	Customer Meter	A vehicle impact into a service meter and riser at 3344 Rio Linda Blvd in Sacramento caused an unintentional release of gas.	Closed
20141104-01	SDG&E	Media Coverage	Service Line	A third-party contractor struck and damaged a 1" plastic gas service line causing a release of gas.	Closed

20141105-01	SDG&E	Media Coverage	Main	A third-party contractor struck 2" plastic gas line at the corner of Regents Rd. and La Jolla Village Dr.	Closed
20141105-02	PG&E	Media Coverage	Main	A third-party contractor dug into a 4" plastic distribution main in Alamo near the intersection of Livorna Road and Wilson Road.	Closed
20141105-03	SDG&E	Media Coverage	Service Line	A third party contractor hit and damaged a 1/2" plastic service line. This incident was reported due to media coverage.	Closed
20141105-04	SDG&E	Media Coverage	Service Line	A third party contractor hit a 1/2" PE service line while excavating. This incident was reported due to media coverage.	Closed
20141106-01	SDG&E	Media Coverage	Main	A third contractor struck 2" plastic gas main at the corner of Regents Rd. and La Jolla Village Dr. This incident was reported due to media coverage.	Closed
20141107-01	PG&E	Damages Above 50K	Main	A third-party excavator struck and damaged a 4" plastic distribution main at 1 S. Market St., San Jose.	Closed
20141110-01	SoCalGas	Media Coverage	Service Line	A third-party contractor was working to install new signs for shopping center complex and struck a 2" plastic line with an auger. This incident is reported due to media coverage.	Closed
20141113-01	SoCalGas	Media Coverage	Service Line	A third-party contractor was trenching to install irrigation system and struck a 1" plastic service line. This incident was reported due to media coverage.	Closed
20141116-02	PG&E	Damages Above 50K	Customer Meter	A vehicle struck and damaged a five-meter manifold riser in San Jose, CA and caused release of natural gas which subsequently ignited.	Closed
20141120-01	SoCalGas	Damages Above 50K	Transmission	A farm tractor ripped SoCalGas Transmission Line #203 resulting release natural gas into atmosphere. There were no injuries or fatalities.	Closed
20141120-02	SoCalGas	Casualties or Inpatient Hospitalization	Service Riser	A structure fire was reported where an illegal bypass on a gas meter found. The incident was reported to DOT due to 2 fatalities and injuries.	Closed
20141121-01	SDG&E	Media Coverage	Service Line	A third party excavator hit a 3/4" steel pipe. The incident became reportable due to media onsite.	Closed
20141122-01	SDG&E	Media Coverage	Customer Meter	A vehicle hit a meterset assembly causing a leak. The incident became reportable due to media on scene.	Closed
20141125-01	SoCalGas	Media Coverage	Main	A third party contractor struck a 2" plastic pipe. This became reportable due to media on scene.	Closed
20141128-01	PG&E	Casualties or Inpatient Hospitalization		Report of an explosion in an apartment resulting in one injury. It was later determined that natural gas was involved in the incident.	Closed
20141129-01	SoCalGas	Media Coverage	Service Line	A vehicle ran into a gas meterset assemblies causing a release of gas. Incident became reportable upon the arrival of unknown media.	Closed
20141204-01	SoCalGas	Media Coverage	Service Riser	Flash flood water broke a 3/4" steel service riser causing release of gas.	Closed
20141208-01	SDG&E	Damages Above 50K	Main	A third party contractor hit a 2" Steel gas main resulting approximately 280 customers out of service.	Closed
20141210-01	PG&E	Damages Above 50K	Customer Meter	A structure fire affecting two adjacent houses at 1928 and 1932 Robertson Road in Modesto melted a meterset assembly causing release of gas.	Closed
20141210-02	PG&E	Operator Judgement	Transmission	PG&E field personnel reported a suspicious device discovered near natural gas transmission pipeline Line 314 approximately one mile west of Hinkley Compressor Station (35863 Fairview Rd, Hinkley). This did not result in a release of gas. There were no injuries, fatalities or property damage reported.	Closed
20141212-01	SoCalGas	Media Coverage		A natural gas leak was reported due to forces from mudslides at Camarillo Springs, a gated community. This was reported due to a gas leak and media coverage.	Closed

20141212-02	PG&E	Media Coverage	Main	A third-party struck a 2" plastic distribution main while operating a backhoe at 977 East Hillside Blvd in Foster City (shopping center).	Closed
20141218-01	PG&E	Gas Loss	Valve	An 8-inch pressure relief on PG&E's 34-inch transmission line L-300B at pressure limiting station, PLS4, in Arvin, Kern County, malfunctioned resulting in an unintentional release of gas to the atmosphere.	Closed
20141221-01	PG&E	Media Coverage	Customer Meter	PG&E called to scene after a gun exchange between an armed man at the residence and police is thought to have struck the house meter and then ignite causing a structure fire that burned the house completely.	Closed
20141221-02	SoCalGas	Media Coverage	Customer Meter	A tree branch fell on top of a commercial-sized 9-meterset assembly causing a gas leak. This was reported due to media coverage.	Closed
20141222-01	SoCalGas	Casualties or Inpatient Hospitalization	Service Line	A third party contractor was excavating with an electric chipping hammer when he struck a service line causing a gas leak. This incident was reported due to possible hospitalization of the contractor and media coverage. The contractor was transported to local hospital with unknown injuries and was reportedly released.	Closed
20141223-01	PG&E	Damages Above 50K	Transmission	PG&E crews were performing a routine leak inspection and repair on a non-hazardous leak on PG&E's transmission line (L-50A MP 31.64) on Hwy 99 just south of Skillin Road, Oroville. The crews observed that the leak continued to migrate through the excavation and became a hazardous leak requiring immediate repair. A pin-hole leak due to external corrosion was identified. The incident was reported to DOT and CPUC as the cost of the incident was estimated to exceed \$50,000.	Open
20141228-01	SoCalGas	Media Coverage	Customer Meter	Vehicle hit gas facilities at 1378 N Towne Ave in Pomona, Los Angeles.	Closed
20141230-01	PG&E	Damages Above 50K	Valve	PG&E crews were performing routine maintenance work on an automated valve on PGE's 6-inch transmission line L105N, when a leak on a 6" blow off valve was observed.	Closed
20150108-01	PG&E	Media Coverage	Customer Meter	A vehicle impact damaged a gas meter set causing a release of gas.	Closed
20150109-01	SDG&E	Media Coverage	Service Line	A third-party contractor struck and damaged a 1-1/4" inch plastic service line causing a release of gas.	Closed
20150109-02	PG&E	Gas Loss	Transmission	An 8-inch pressure relief valve (on PG&E's 34-inch transmission line L-300B at pressure limiting station, 4-PLS) in Arvin opened prior to reaching its set point of 721 psig-resulting in an unintentional release of natural gas.	Closed
20150110-01	PG&E	Operator Judgement	Regulator	A structure fire at 1161 34th Street, Oakland CA damaged a gas meterset assembly that caused an unintentional release of gas.	Closed
20150112-01	SDG&E	Media Coverage	Main	A third party contractor damaged a 3" gas main resulting in a gas leak. This incident was reported due to media coverage.	Closed
20150112-02	PG&E	Operator Judgement	Customer Pipe	While PG&E maintenance personnel were performing routine maintenance work on the meter set at the Alameda Hospital, located at 2070 Clinton Ave, Alameda CA, slag from the distribution main accumulated between the boot and orifice causing the regulator to fail resulting in an unintentional release of gas in the hospital boiler room.	Closed
20150114-01	SoCalGas	Media Coverage	Service Line	The third-party contractor was boring to install a conduit when they struck a 2" plastic service. The incident later became reportable due to media follow up questions from the OC Register on the SoCalGas media hotline.	Open
20150115-01	SDG&E	Media Coverage	Service Riser	An unknown person threw a concrete block at a service riser in an abandoned building. The incident became reportable due to media presence.	Closed
20150116-01	SoCalGas	Media Coverage	Main	A third party contractor was excavating and struck a 3" plastic main causing a gas leak. This incident was reported due to media	Closed

				coverage.	
20150119-01	SoCalGas	Media Coverage	Main	A third party contractor struck a 3" plastic main while excavating to locate electrical and reclaimed water. Reported due to media coverage.	Closed
20150120-01	PG&E	Operator Judgement	Service Line	A third-party was boring a conduit when it damaged a 1-1/4" steel stub at 2160 Tully Road, San Jose. The incident was reported due to evacuations in the area.	Closed
20150121-01	PG&E	Media Coverage	Regulator	A structure fire at 7505 Hamil Ct. Sacramento spread and melted the gas meter and riser, causing an unintentional release of gas.	Closed
20150121-02	PG&E	Operator Judgement	Service Riser	A structure fire at 1049 Pucheu St., Mendota melted the meter and riser causing a release of gas.	Closed
20150122-01	SDG&E	Media Coverage	Main	A third-party contractor damaged and hit a 2" plastic main. Reported due to media coverage.	Closed
20150122-02	PG&E	Media Coverage	Main	A third-party was using a backhoe to fix a water service when they struck a 2" plastic main at 507 Lyon St, San Francisco.	Closed
20150122-03	SDG&E	Media Coverage	Service Line	A third-party contractor struck and damaged a 1/2" gas service. This incident was reported due to media coverage.	Closed
20150125-01	PG&E	Damages Above 50K	Service Riser	A structure fire at 22787 Alder Street in Chowchilla melted the meter and the riser valve causing a release of gas.	Closed
20150126-01	PG&E	Damages Above 50K	Valve	A vehicle impacted a gas meter resulting a release of gas which ignited and caused a structure fire at a 992 El Camino Real in San Bruno.	Closed
20150128-01	PG&E	Gas Loss	Transmission	A pressure limiting valve on PG&E's 34-inch transmission line L-300B (at pressure limiting station PLS-4) in Arvin opened resulting in an unintentional release of natural gas to the atmosphere.	Closed
20150128-02	PG&E	Media Coverage	Service Line	A third-party contractor struck and damaged a 2" steel main causing an intentional release of gas at 1855 Alum Rock Avenue in San Jose.	Closed
20150129-01	SoCalGas	Media Coverage	Service Line	A third-party construction crew working to frame steps prior to pouring cement, dug a stake into a 1" plastic service line. The construction crew then dug a hole using a metal shovel that created a spark, resulting in a fire.	Closed
20150130-01	SoCalGas	Damages Above 50K	Main	A big truck caught a cable from the power pole while driving, dragged the cable and eventually knocked down the pole. The energized power line caused a leak on the gas line and ignited the gas.	Closed
20150210-01	SoCalGas	Media Coverage	Service Riser	A third-party contractor was working for weed and trash abatement on a vacant lot when he struck a 1/2" plastic service riser causing a gas leak.	Closed
20150211-01	SDG&E	Media Coverage	Service Line	A third party contractor was excavating when he struck a 1" plastic service line causing a gas leak. This incident was reported due to media coverage.	Closed
20150212-01	PG&E	Media Coverage	Service Line	A customer was performing work near the gas service riser and damaged the service valve.	Closed
20150213-01	SoCalGas	Media Coverage	Customer Meter	The driver of a stolen vehicle drove the vehicle into a house and damaged the meter set assembly. This resulted in gas leak.	Closed
20150218-01	PG&E	Media Coverage	Main	Customer reported smell of gas out in street, hissing at cracks in sidewalk later determined to be caused from a leaking service tee cap.	Closed
20150219-01	SoCalGas	Media Coverage	Customer Meter	Vehicle hit a 3-meter manifold causing release of gas.	Closed
20150219-02	SoCalGas	Media Coverage	Service Riser	Vehicle hit gas riser causing release of gas.	Closed
20150220-01	SDG&E	Media Coverage	Service Riser	A forklift struck a 3/4" plastic service riser causing a gas leak. This incident became reportable until SDG&E recently learned of media involvement.	Open
20150226-	SoCalGas	Media	Main	A third party was excavating with a backhoe and struck a 4" plastic	Closed

01		Coverage		main causing a gas leak.	
20150226-02	PG&E	Media Coverage	Service Line	A third-party excavator struck and damaged a 1/2" plastic service line at 1066 Stockton Street in San Francisco.	Closed
20150227-01	PG&E	Damages Above 50K	Main	A third-party struck and damaged an 8" plastic main with a backhoe at Elk Grove Florin Perkins & Gerber Rd, in Sacramento.	Closed
20150228-01	PG&E	Damages Above 50K	Transmission	A third party damaged a 10" steel distribution feeder main DFM1815-15 while doing road clearing/grading work near 610 Viejo Rd in Carmel-By-The-Sea that resulted in an unintentional release of gas.	Closed
20150301-01	SoCalGas	Media Coverage	Customer Meter	A vehicle struck a meterset assembly resulting in damage and the subsequent gas leak. A fatality occurred due to the vehicle crash but was not related to escaping gas. This incident was reported due to media coverage.	Closed
20150303-01	PG&E	Media Coverage	Main	A third party struck and damaged a 4" plastic distribution main at 1375 Sycamore Ave in Hercules that resulted in an unintentional release of gas.	Closed
20150304-01	PG&E	Media Coverage	Main	A third-party struck a 2" plastic distribution main with an auger at 3737 Casa Verde St in San Jose.	Closed
20150310-01	SDG&E	Media Coverage	Customer Meter	A vehicle struck a gas meter causing a gas leak. This incident was reported due to media coverage.	Closed
20150313-01	SoCalGas	Media Coverage	Service Riser	Structure fire occurred in detached building with kitchen equip. Fire engulfed meterset assembly causing ignited gas release	Closed
20150314-01	SDG&E	Media Coverage	Service Line	A contractor working for homeowner damaged a 1 ¼" plastic service serving a house while digging. Incident reported due to media on scene.	Closed
20150321-01	PG&E	Operator Judgement	Service Line	A structure fire at 8794 Almond Avenue in Dos Palos melting the service riser and valve resulting in a release & ignition of gas.	Closed
20150323-01	PG&E	Media Coverage	Customer Meter	A vehicler impacted a gas meter at 4045 Cabrillo Street in San Francisco causing a release of gas.	Closed
20150324-01	SoCalGas	Media Coverage	Customer Meter	A power pole was knocked down and landed on a meterset assembly, breaking the nipple between the shutoff valve and the regulator. This incident was reported due to media coverage	Closed
20150327-01	SoCalGas	Media Coverage	Service Riser	A vehicle struck a ½" plastic service riser causing a gas leak. his incident was reported due to media coverage.	Closed
20150406-01	SoCalGas	Media Coverage	Main	A third party contractor was excavating for water and struck a 2" plastic main. This incident was reported due to media coverage.	Closed
20150407-01	SoCalGas	Media Coverage	Main	A third party contractor was excavating with a backhoe and struck a 2" plastic gas main. This incident was reported due to media coverage. S	Closed
20150410-01	SDG&E	Media Coverage	Service Riser	A vehicle struck our gas meter causing a leak. This incident became reportable due to media presence.	Closed
20150413-01	PG&E	Damages Above 50K	Transmission	A third party excavator struck and damaged a 10" steel transmission line (L-220) mile point (MP) 6.71 while excavating an irrigation ditch, which resulted in an unintentional release of natural gas.	Closed
20150417-01	PG&E	Casualties or Inpatient Hospitalization	Transmission	A third party grading on a Fresno County Sheriff's shooting range at 7633 N. Webber Ave, Fresno punctured the 12" steel gas transmission main (L-118) while grading at the foot of slope. Incident resulted in a fatality.	Open
20150420-01	PG&E	Media Coverage	Service Line	A structure fire at a mobile home park (261 Wilbur Ave. #12, in Yuba City) damaged the meter set causing a release of gas.	Closed
20150422-01	PG&E	Media Coverage	Service Line	A third party contractor boring for a new fiber optic line struck and damaged a 1" plastic service line dig-in at 1340 Willow Rd. in melo Park causing an unintentional release of gas.	Closed
20150423-01	PG&E	Media Coverage	Main	A third-party excavator struck and damaged a 4" plastic distribution main at the intersection of Buchanan Rd and Somersville Rd in Antioch that resulted in an unintentional release of gas.	Closed
20150423-	PG&E	Operator	Customer	A structure fire at 897 Sanitarium Rd in Deer Park in which the	Closed

02		Judgement	Meter	service riser and meter were destroyed causing an unintentional release of gas.	
20150424-01	SoCalGas	Media Coverage	Service Line	A contractor was excavating when he struck a 1" plastic service causing a gas leak. This incident was reported due to media coverage.	Open
20150428-01	SoCalGas	Media Coverage	Service Line	A 1" plastic service was hit by a third party contractor causing a release of gas. Incident is being reported due to media inquiries.	Closed
20150429-01	PG&E	Media Coverage	Main	A third-party contractor struck and damaged a 2" plastic main with a backhoe on the corner of Masonic and Haight in San Francisco, causing an unintentional release of gas.	Closed
20150506-01	SDG&E	Media Coverage	Service Riser	A vehicle backed into a gas service riser causing a release of gas. This incident is being reported due to media coverage.	Open
20150507-01	PG&E	Damages Above 50K	Transmission	A PG&E crew smelled gas at the corner of Garden Hwy & Lincoln Hwy in Yuba City. A grade 1 leak was discovered on a girth weld on DFM 1501-01.	Open
20150507-02	PG&E	Media Coverage	Customer Meter	A structure fire in a demolished house spread to the house next door (1175 Pine Oak Rd.) and melted the gas meter and regulator.	Closed
20150508-01	SoCalGas	Damages Above 50K	Main	Water discovered in the gas line. The company determined the possibility of the associated damage exceeding \$50,000.	Open
20150514-01	PG&E	Media Coverage	Customer Meter	A lightning strike on a flag pole at 4715 Montclair, Granite Bay arced to the customer's electric service which was grounded to the water pipe and bonded to the customer's gas house line, causing damage to nylon bushing and a small release of gas.	Closed
20150516-01	SoCalGas	Gas Loss	Main	A third-party excavator hit a 6" plastic main causing a release of gas.	Open
20150520-01	PG&E	Media Coverage	Service Line	A third-party contractor was working in an open excavation for the MUNI tunnel project when the excavation partially collapsed and concrete fell onto a 1" plastic distribution service line causing an unintentional release of gas.	Closed
20150521-01	SoCalGas	Media Coverage	Service Line	A third party excavator damaged 1/2" plastic service line. The incident was reported under the media coverage criteria.	Open
20150526-01	PG&E	Operator Judgement	Valve	A structure fire at a vacant house at 116 Martin St in Vallejo melted a meterset causing a release of gas.	Closed
20150527-01	SoCalGas	Media Coverage	Main	A third-party contractor was working to relocate sewer utilities for Metro Project and struck a 2" plastic main. This incident was reported due to media coverage.	Closed
20150528-01	SDG&E	Media Coverage	Service Riser	Vehicle backed into a meter, causing a gas leak. This incident was reported due to media coverage.	Closed
20150529-01	SoCalGas	Media Coverage	Main	A third-party contractor observed and reported a gas leak on a 2" steel main later determined to be caused by external corrosion. This incident was reported when SoCalGas became aware of media coverage.	Closed
20150601-01	PG&E	Damages Above 50K	Customer Meter	A structure fire at 56 W. Bolivar Street, Salinas damaged the meterset causing a release of gas.	Closed
20150602-01	PG&E	Media Coverage	Main	A PG&E electric crew struck and damaged a 3" steel gas main. Nearby homes and at least three Chico State University buildings were evacuated. Media (Telemundo Chico, KRCC, etc.) was observed on site.	Closed
20150602-02	SoCalGas	Media Coverage	Main	A third-party contractor boring to install traffic signs struck a 2-inch plastic main. The Incident was reported due to media inquiries.	Closed
20150609-01	PG&E	Media Coverage	Service Line	A third-party struck and damaged a 2" plastic stub at Great Oaks and Lexington in an undeveloped area of San Jose.	Open
20150610-01	SoCalGas	Media Coverage	Service Line	A third-party contractor was excavating for landscape and struck a 1" plastic service. This incident was reported when SoCalGas became aware of media coverage.	Open
20150611-01	PG&E	Operator Judgement	Valve	A structure fire at 217 E. Warren Avenue, Bakersfield CA that caused an unintentional release of gas.	Open

20150611-02	SoCalGas	Media Coverage	Main	A third-party contractor was excavating when he struck a 2" plastic main causing a gas leak.	Closed
20150612-01	PG&E	Operator Judgement	Service Riser	A structure fire at 5540 Robertson Ave, Carmichael (Sacramento) melted the meter causing a release of gas.	Closed
20150618-01	PG&E	Casualties or Inpatient Hospitalization	Service Riser	A structure fire at Hartnell St. and Alvarado Niles Rd in Union City that may have damaged the 5-meter manifold, causing an unintentional release of gas. The incident resulted in a fatality.	Closed
20150618-02	PG&E	Operator Judgement	Service Line	A multiple structure fire melting a gas meter at 7915 McHenry Ave in Modesto, causing a release of gas.	Open
20150621-01	PG&E	Media Coverage	Regulator	A gas leak was reported at 582 Hope St in Mountain View. The cause of the leak was found to be a failed rubber gasket on a distribution feeder main regulator station.	Open
20150622-01	PG&E	Media Coverage	Service Line	A third-party contractor was trnching when they strucj a 1/2" plastic service at 172 Forest Side Ave in San Francisco causing an unintentional release of gas.	Closed
20150622-02	PG&E	Operator Judgement	Customer Meter	A structure fire at 5834 Corte Margarita in Pleasanton that damaged a customer meter causing an unintentional release of gas from PG&E facilities. The fire was determined to have started in a garbage can near the meter.	Closed
20150622-03	PG&E	Media Coverage	Customer Meter	A vehicle impact into a customer meter at 3165 Gardendale Dr in San Jose caused an unintentional release of gas.	Closed
20150625-01	PG&E	Damages Above 50K	Service Riser	A vehicle impact incident at 8239 Don Avenue in Stockton caused an unintentional release of natural gas and ignition.	Closed
20150626-01	PG&E	Damages Above 50K	Service Line	A residential structure fire at 121 Robinson Circle, Healdsburg Ca, in Sonoma County damaged the meterset assembly causing a release of gas.	Closed
20150628-01	SoCalGas	Media Coverage	Customer Meter	A vehicle broke a curb vault resulting in a damaged stop cock. The incident became reportable due to media coverage.	Closed
20150630-01	SoCalGas	Media Coverage	Customer Meter	A vehicle hit meter damaged 5 meter manifold. Electrical panel fell on manifold causing a leak to ignite. The incident became reportable due to media coverage.	Open
20150630-02	PG&E	Media Coverage	Service Line	A third-party contractor excavating for a water service installation damaged a 1" plastic service line while using an acetylene torch to solder on the copper water service, causing a release of gas and its subsequent ignition.	Closed
20150701-01	SoCalGas	Media Coverage	Main	A third-party contractor was digging with a tunnel bar when he struck a 2" plastic main causing a gas leak.	Closed
20150706-01	PG&E	Media Coverage	Service Line	A gas odor was reported at a duplex at 4706 Large Oak Court in Sacramento. A leak was discovered on a 1/2" plastic service line which appeared to have been punctured by a plumbing snake used in the sewer line.	Open
20150707-01	PG&E	Media Coverage	Main	A third party struck and damaged a 2" plastic main at 250 Harris Avenue, Ste. 3 in Sacramento.	Closed
20150707-02	SoCalGas	Media Coverage	Customer Meter	A vehicle hit a structure at 5440 Breckenridge Ave and continued to roll downhill where it struck a meterset assembly at 5448 Breckenridge Ave causing a gas leak.	Closed
20150711-01	SDG&E	Media Coverage	Service Line	A third-party contractor hit and damaged a 3/4" steel service line while grinding a tree stymp causing a release of gas.	Closed
20150712-01	PG&E	Media Coverage	Customer Meter	A vegetation fire spread to a nearby structure at 4904 Snow St. San Jose damaging the gas meterset assembly.	Closed
20150712-02	SDG&E	Media Coverage	Service Riser	A vehicle hit gas riser causing a release of gas.	Closed
20150713-01	PG&E	Operator Judgement	Customer Meter	A structure fire damaged a gas meterset assembly causing a release of gas.	Closed
20150713-02	PG&E	Media Coverage	Main	A PG&E crew performing a leak repair damaged a fitting on a 4" main. Being reported to CPUC due to unknown media onsite	Open

20150714-01	PG&E	Operator Judgement	Main	A third-party excavator struck and damaged a 4" plastic main at N MacArthur and W 11th st, Tracy, causing a loss of service to 50 customers. The incident was reported to the CPUC due to public attention.	Closed
20150714-02	SoCalGas	Damages Above 50K	Main	Contractor was excavating when he struck a 6" steel main. This incident was reported to the CPUC and DOT due to the associated damage that could potentially exceed \$50,000.	Open
20150720-01	PG&E	Media Coverage	Service Riser	A Safeway Supermarket employee sheared off the 3/4" steel service riser at 15551 Union Ave, in Los Gatos causing a release of gas.	Closed
20150723-01	PG&E	Operator Judgement	Customer Meter	A structure fire at 6507 6th Street, Riverbank CA that caused an unintentional release of gas with ignition.	Closed
20150724-01	SDG&E	Media Coverage	Service Line	Contractor struck a 1" plastic service with a backhoe causing a gas leak. There were no injuries as a result of the gas leak. Crew is on scene working to control the gas. This incident was reported to the CPUC when SDG&E became aware of media coverage.	Closed
20150727-01	PG&E	Operator Judgement	Customer Regulator	Structure fire melted gas meter and regulator.	Open
20150727-02	SoCalGas	Media Coverage	Other	A third-party contractor hit a 3/4" steel cutback service with a backhoe causing a release of gas. This incident was reported to the CPUC due to media involvement.	Closed
20150804-01	SoCalGas	Media Coverage	Main	A third-party contractor was excavating for tree removal with a backhoe when he struck a 2" plastic main causing a gas leak.	Open
20150806-01	PG&E	Casualties or Inpatient Hospitalization	Customer Meter	An explosion at a home's gas stove caused a fire at a mobile home park in Bakersfield located at 3535 Stine Road, space 192. Space 191 along with two other units appears to have been damaged as well.	Open
20150810-01	PG&E	Operator Judgement	Regulator	On August 10, 2014 at 0440 hours, PG&E was notified of a structure fire, of unknown cause, at 1136 72nd Avenue in Oakland. When PG&E's GSR arrived on site at approximately 0515 hours, the meter set was on fire and it was not safe to approach the home howe	Open
20150812-01	SoCalGas	Damages Above 50K	Customer Meter	A vehicle struck a meterset in a restaurant parking lot, which resulted in a release of gas and a fire.	Closed
20150816-01	SDG&E	Media Coverage	Customer Meter	House fire (cause still unknown) damaged gas meter, resulting in a release of gas. Crews are currently working to control the gas. No injuries have resulted from this incident. The incident was reported due to media coverage and the possibility of damage	Open
20150817-01	PG&E	Media Coverage	Service Line	A third-party doing road patchwork when the hot asphalt seeped through an opening and melted the 1-1/4" plastic service line causing a release of gas,	Closed
20150818-01	PG&E	Media Coverage	Main	At 0725 hours PG&E call center was notified of an odor complaint at 339 15th Ave., San Francisco. PG&E GSR arrived on site at 0810 hours. A leak was found on a 2-inch plastic distribution main. At approximately 1030 hours media was observed on site making	Closed
20150819-01	SoCalGas	Media Coverage	Service Line	A third party contractor damaged an 1" service line releasing gas at 223 North San Luis street in Los Angeles.	Open
20150820-01	PG&E	Media Coverage	Main	A 4" plastic main in Hollister was damaged by a third party dig in.	Open
20150820-02	PG&E	Media Coverage	Main	A 3/4" steel main in Sacramento was damaged by a third party dig in.	Open
20150820-03	PG&E	Media Coverage	Main	A 1 1/4" plastic main in Concord was damaged by a third party dig in.	Closed
20150821-01	SDG&E	Media Coverage	Service Line	A 1/2" PE service was damaged by third party excavation, causing a release of gas.	Closed
20150824-01	SDG&E	Media Coverage	Other	Tree in nursery fell onto meterset and 2" riser. Became reportable when SDG&E learned of TV media presence.	Closed

20150826-01	PG&E	Damages Above 50K	Customer Meter	A vehicle impacted a meterset at a commercial building at 2935 White Oak in Santa Clara, resulting in an unintentional release of gas that subsequently	Closed
20150829-01	PG&E	Operator Judgement	Regulator	A structure fire at 3194 Moorpark Ave in San Jose damaged the meterset assembly causing a release of gas.	Closed
20150830-01	SDG&E	Media Coverage	Customer Meter	A vehicle drove through a fence, struck a riser and meter manifold resulting in a gas leak.	Open
20150901-01	PG&E	Media Coverage	Service Line	A PG&E's contractor struck ¾" steel service line, with a backhoe, causing a release of gas.	Closed
20150901-02	SDG&E	Media Coverage	Main	Contractor struck a plastic gas line resulting in a leak. Crew is on scene working to control the gas. There were no injuries or evacuations. This incident was reported when SDG&E became aware of media coverage.	Open
20150903-01	SoCalGas	Media Coverage	Main	Contractor was digging with a ripper when he struck a 6" plastic gas main resulting in a leak. Crew is on scene working to control the gas. This incident was reported to CPUC when SoCalGas became aware of media coverage.	Open
20150903-02	SoCalGas	Media Coverage	Main	A third party contractor hit a 2-inch plastic main with a mini excavator while excavating a trench to install fiber optics	Closed
20150905-01	SDG&E	Media Coverage	Service Riser	A vehicle struck and damaged a service riser at 8045 Fletcher Parkway in La Mesa.	Open
20150908-01	PG&E	Media Coverage	Main	A third-party performing irrigation work damaged the gas main at 2752 Bette Street in Alameda.	Closed
20150909-01	SoCalGas	Media Coverage	Customer Meter	A tree fell on the roof of a residence snapping the houseline and damaging the meterset assembly resulting in a gas leak.	Closed
20150910-01	PG&E	Media Coverage	Service Line	A third-party struck a 1/2-inch plastic inserted into a 3/4-inch steel line with a concrete cutter that resulted in a release of gas.	Closed
20150912-01	SoCalGas	Media Coverage	Service Line	While making emergency repairs to an electrical line, PG&E crew struck a 1/2" gas service. This incident was reported due to the presence of media.	Closed
20150914-01	SoCalGas	Damages Above 50K	Customer Meter	A structure fire reported at 531 N Lomita St, Burbank. Crew responded and found the inlet to an MSA found broken. This was reported to CPUC and DOT due to a gas leak and the associated damage possibly exceeding \$50,000.	Open
20150915-01	SoCalGas	Media Coverage	Customer Pipe	Heavy rain caused land erosion to a portion of a house to slide into a wash. As a result, the downstream piping of the regulator at the meterset was damaged causing a gas leak.	Closed
20150918-01	PG&E	Operator Judgement	Customer Meter	A structure fire at 108 El Camino Real in Greenfield melted a meter causing an unintentional release of gas.	Open
20150918-02	PG&E	Operator Judgement	Customer Meter	A structure fire at 1920 Ocean St in San Francisco that melted a meter causing an unintentional release of gas.	Closed
20150922-01	SDG&E	Media Coverage	Service Line	A 1-1/4" plastic service was struck by third party excavation, resulting in a leak.	Closed
20150922-02	SDG&E	Media Coverage	Service Line	A 1" steel service was struck by third party excavator, resulting in a leak.	Open
20150923-01	PG&E	Damages Above 50K	Customer Meter	Structure fire involving two homes damaged PG&E's meter sets. Incident reported due to costs of damages related to the fire exceeding \$50,000.	Open
20150923-02	SoCalGas	Media Coverage	Service Line	A third party contractor struck and damaged a 3/4" steel service line causing a leak.	Open
20150924-01	SDG&E	Media Coverage	Other	A Third party contractor stuck 3" steel main with a trackhoe. This was reported to CPUC when SDG&E became aware of media coverage.	Open
20150928-01	SDG&E	Media Coverage		A third party excavator damage of 2" plastic gas main. This was reported to CPUC when SDG&E became aware of media coverage.	Open
20150929-01	SDG&E	Media Coverage	Main	A third party excavation damage of 3" plastic gas main. This was reported to CPUC when SDG&E became aware of media coverage.	Closed

20151003-01	SDG&E	Media Coverage	Service Riser	A vehicle crashed through brick wall, into a house and damaged a steel riser. This become reportable when TV media arrived.	Open
20151006-01	SoCalGas	Media Coverage	Main	A third party contractor struck a 4" plastic main. Gas is under controlled at 11:28 am. No injuries and no ignitions. This became reportable when SoCalGas became aware of media coverage.	Open
20151006-02	PG&E	Media Coverage	Service Line	A third party contractor doing pipe bursting on a sewer lateral da,ahed a 3/4" steel service line causing a gas leak.	Open
20151006-03	PG&E	Media Coverage	Customer Regulator	PG&E was notified of a Natural Gas related structure fire. At this time, the cause of the fire is unknown.	Open
20151006-04	SoCalGas	Media Coverage	Valve	Fire Department reported a leaking valve at a regulator station. This was reported to CPUC when SOCALGAS became aware of media coverage.	Open
20151007-01	SoCalGas	Media Coverage	Customer Meter	Major fire swept through over a dozen businesses,melting the meterset assemblythat ignited.	Open
20151009-01	PG&E	Media Coverage	Service Line	A third-aprty contractor stuck a 1" plastic service line with a shovel causing an unintentional release of gas.	Closed
20151012-01	SoCalGas	Media Coverage	Service Line	A 1/2" plastic service was struck by third party excavation, resulting in a leak.	Closed
20151013-01	PG&E	Media Coverage	Other	A third-party contractor stuck a 2" plastic distribution main with an auger causing an unintentional release of gas.	Open
20151015-01	SoCalGas	Casualties or Inpatient Hospitalization	Service Line	A third party contractor struck a ½" plastic service line causing a gas release. Contractor was flashed and taken to local hospital. His conditions are unknown at this time. This incident was reported to DOT and CPUC due to a gas release and an injured co	Open
20151015-02	SoCalGas	Media Coverage	Service Line	Third party contractor struck 1/2" plastic service while digging for sewer. This was reported to CPUC when SoCalGas became aware of media coverage.	Closed
20151019-01	SDG&E	Media Coverage	Main	Third party contractor struck a 3" plastic main causing a gas leak. This was reported to CPUC when SoCalGas became aware of media coverage.	Closed
20151020-01	SoCalGas	Media Coverage	Service Line	Landscaping contractor damaged plastic service line causing a leak. Reported due to media coverage.	Closed
20151020-02	SoCalGas	Media Coverage	Main	Third party contractor was excavating struck a 2" plastic main resulting in a gas leak. This incident became reportable when SoCalGas became aware of med	Closed
20151023-01	PG&E	Damages Above 50K	Transmission	Agricultural dig-in on transmission line 150 in Winters. No injuries, fatalities, or ignition. 6-inch line severed causing release of gas.	Open
20151025-01	SoCalGas	Operator Judgement	Other	Leak from an existing Aliso Canyon gas storage well. No ignition, no injury. No media. Notification due to operator judgement only. Reported to DOGGR. Failure under investigation.	Open
20151027-01	PG&E	Media Coverage	Main	A PG&E contract crew was backfilling over a 2-inch electrofusion fitting that had just been installed and put in service when it was observed that the fitting began leaking.	Open
20151028-01	SoCalGas	Media Coverage	Customer Meter	A structure fire was reported at 1258 N Coates Ave, Los Angeles. The fire charred the meter dial causing gas to escape and ignition.	Open
20151029-01	SDG&E	Media Coverage		Third party contractor struck a ½" plastic service. This was reported when SDG&E became aware of media coverage.	Open
20151029-02	PG&E	Damages Above 50K	Main	A contractor performing boring hit a 6-inch gas distribution main. No injuries, fatalities, or ignition.	Closed
20151031-01	SDG&E	Media Coverage	Service Line	A third party contractor was excavating and they struck a 1.25" PL service resulting in a leak. This incident was reported due to media presence.	Open
20151103-01	PG&E	Media Coverage	Main	A third party contractor removing a tree stump damaged a 4-inch steel gas distribution main at 525 Fitch St Healdsburg.	Closed

20151104-01	PG&E	Operator Judgement	Customer Meter	A structure fire at 1451 Conestoga Dr, Merced, started by hot charcoals in a garbage can, melted a nearby two-meter manifold and regulator resulting in a release of gas.	Open
20151105-01	SoCalGas	Media Coverage	Customer Meter	A vehicle struck the meterset assembly resulting in a gas leak. There was no ignition. This incident was reported due to media interest.	Closed
20151105-02	SDG&E	Media Coverage	Main	A third party contractor struck the 2" plastic main with a digging bar. This incident was reported due to media interest.	Open
20151106-01	PG&E	Media Coverage	Main	A third-party excavator struck a 2-inch plastic main causing a release of gas.	Open
20151106-02	SDG&E	Media Coverage	Service Line	A third party contractor stuck a ½" plastic service. This incident was reported to CPUC when SDG&E became aware of media coverage.	Open
20151107-01	PG&E	Media Coverage	Service Riser	A vehicle impact at the intersection of San Felipe Road and Meadowlands Lane in San Jose hit an RTU ½ inch plastic sense line causing a release of gas.	Open
20151109-01	PG&E	Casualties or Inpatient Hospitalization	Service Riser	A structure fire at 127 E. Grove Street in Stockton melting the gas meter. The incident resulted in a fatality.	Open
20151109-02	SoCalGas	Media Coverage	Other	Semi truck hit a building damaging meter causing a release of gas.	Closed
20151109-03	PG&E	Damages Above 50K	Customer Meter	A structure fire at 28281 Black Gold Way in Tehachapi melted the gas meter causing a release of gas.	Open
20151110-01	PG&E	Media Coverage	Service Riser	A semi-truck had lost control and damaged the 1-1/4" service line above the riser valve causing a release of gas.	Open
20151113-01	PG&E	Casualties or Inpatient Hospitalization	Transmission	A ripper struck L300A at MP 269, 34" transmission line at Wible Rd & Engle Rd in Bakersfield, resulting in a release of gas and subsequent ignition. The incident resulted in a fatality.	Open
20151115-01	PG&E	Media Coverage	Service Line	PG&E was notified of a fire near 4850 Harwood Rd in San Jose. PG&E's repair crew arrived on-site at 1359 hours. The cause of the fire is currently under investigation; however, it appears PG&E's gas facilities were secondarily involved. PG&	Open
20151117-01	SDG&E	Media Coverage	Service Line	A third party contractor struck a 1/2" plastic gas service. This was reported to CPUC when SDG&E became aware of media coverage.	Closed
20151118-01	PG&E	Operator Judgement	Main	PG&E was performing a tie-in on a 2' gas main near Leland and Lynbrook Dr in Pittsburg. In the process, the worker setting up a bypass, inadvertently shut in and squeezed the back side of the 2-inch main, resulting in a service interruption to 90 customers.	Open
20151118-02	SoCalGas	Media Coverage	Service Line	A homeowber struck and damaged a 1/2" plastic service line while doing landscaping.	Open
20151123-1928	SoCalGas	Media Coverage	Service Line	A third party contractor was digging for plumbing when he struck a 1/2" plastic service causing a release of gas. This incident was reported to CPUC when SoCalGas became aware of media coverage.	Closed
20151125-1929	SDG&E	Media Coverage	Service Line	A third party contractor digging and struck a 1-1/4" plastic service causing a release of gas. No injuries. This was reported to CPUC due to media.	Open
20151202-1931	SoCalGas	Media Coverage	Service Riser	While attempting to turn off the gas, the maintenance personnel at a school broke the tang on the stop cock causing a release of gas. This incident was reported due to media coverage.	Open
20151204-1933	PG&E	Media Coverage	Main	A third-party contractor hit and damaged a 1 ¼" plastic main with a backhoe.	Open
20151207-1934	PG&E	Media Coverage	Customer Meter	A vehicle impact sheared a 1/2" gas riser at 10136 Blossom Ridge Drive, Elk Grove caused an unintentional release of gas.	Open
20151208-1935	SoCalGas	Media Coverage	Main	A third party dug into a 2" plastic main causing a release of gas. This was incident was reported to CPUC due to media inquiry.	Open
20151214-1936	SoCalGas	Media Coverage	Customer Meter	A structure fire damaged the gas meter causing release of gas which ignited.	Open

20151216-1937	PG&E	Operator Judgement	Main	A third party contractor struck a 4" plastic main while using a backhoe in Salinas.	Closed
20151217-1938	SDG&E	Media Coverage	Service Line	A third party contractor hit 3/4" steel service causing release of gas. Incident reported due to media presence.	Open
20151223-1939	PG&E	Media Coverage	Customer Meter	A structure fire at 6730 E. Flint Way, Fresno melted the gas meters causing a release of gas. Per the fire department, the home owner discarded hot coals from a fire place into a trash can located adjacent to PG&E electric and gas meters. The coals started a f	Open
20151227-1940	PG&E	Media Coverage	Regulator	A structure fire at 618 N Fisher, Fresno melted the gas meter and regulator, causing a release of gas.	Open
20151228-1941	PG&E	Operator Judgement	Customer Meter	A structure fire at 2244 Washington St, San Francisco damaged the gas meter causing a release of gas. Damage expected to exceed \$50,000.	Open
20151230-1942	SDG&E	Media Coverage	Service Line	A third party contractor struck a 1-1/4" plastic service with a backhoe causing a release of gas. This incident was reported when SDG&E became aware of media coverage.	Open
20151230-1943	PG&E	Media Coverage	Service Line	A third-party excavator struck and damaged a 1/4" plastic service with a backhoe at 1275 Minnesota St, San Francisco.	Open
20151230-1944	PG&E	Media Coverage	Customer Meter	A structure fire at 1985 N 3rd St, Concord. Per the fire department, the cause of the fire is unknown at this time; however, the house sustained damages that exceed \$50,000.	Open

Safety Incidents Open as of 1-1-2015 and Incidents Reported in 2015

Electric Incidents

(In Compliance with CA Public Utilities Code Section 911 & Senate Bill 1409 signed into law on September 25, 2014)

Incident ID: This number reflects the year, month, the day, the sequence the incident is reported/occurred

Incident Number YYYY-MO-DD-XX	Facility Owner	Reason for Investigation	Facility Type Involved	Brief Description of Incident	Open or Closed as of 12-31-2015
20111101-03	SDG&E	Media attention due to an electrical fire	An overhead 12 kV conductor	An overhead conductor broke and fell to the ground, starting a small grass fire.	CLOSED
20120619-01	PG&E	Fatality	Power plant	A PG&E contractor dismantling a fuel oil tank fell to his death when his man lift was struck by a collapsing tank wall.	CLOSED
20120813-07	PG&E	A third party was injured	An overhead 21 kV conductor	A third party was in an aerial bucket splicing a cable when he received burn injuries from a 21 kV overhead conductor.	CLOSED
20121002-01	PG&E	Outage attracted media attention	An underground splice	On October 1, 2012, an outage occurred on various circuits due to a failed underground splice	CLOSED
20130211-03	SCE	Damage claim	Two overhead 12 kV conductors	A palm frond was dislodged from a palm tree in Garden Grove and resulted in a phase to phase fault which ultimately caused the overhead conductors to fail and ignite structure fires at two homes.	CLOSED

20130303-01	PG&E	Outage attracted media attention	Two 115 kV buses	Two 115 kV buses at a substation tripped. An outage to 58,855 customers resulted.	CLOSED
20130307-01	SCE	Injury due to contact with electric facilities	Overhead 33 kV conductor	An SCE contractor was injured when a de-energized 33 kV conductor he was working on became energized.	CLOSED
20130307-02	PG&E	Injury due to contact with electric facilities	Overhead 12 kV conductor	A third party contractor was injured when he contacted a 12 kV overhead conductor while working on a rooftop.	CLOSED
20130307-03	PG&E	Outage attracted media attention	Substation	An outage occurred to 18,501 customers served by a PG&E substation in the City of Bakersfield.	CLOSED
20130316-01	PG&E	Outage attracted media attention	Three overhead 12 kV conductors	An outage occurred to 3,680 customers in the City of San Francisco due to three spans of a PG&E 12 kV circuit conductor falling to the ground.	CLOSED
20130408-01	SDG&E	Outage attracted media attention	Eight poles	Eight poles failed and fell to the ground during a reportedly high wind event in the area of Borrego Springs.	CLOSED
20130411-01	PG&E	Outage attracted media attention	Crossarm	An outage occurred on a 12 kV circuit due to a broken crossarm. The outage left 1,820 customers without power for approximately 7 ½ hours.	CLOSED
20130422-01	PG&E	Outage attracted media attention	Fuses	An outage occurred to 87 customers on a 21 kV circuit in Gilroy.	CLOSED
20130423-01	PG&E	Outage attracted media attention	Transmission 230 kV line	8,867 customers lost power due to a transmission line failure.	CLOSED
20130425-01	SCE	Fatality	Tap reducing plug	An SCE lineman suffered fatal injuries after inadvertently exposing an energized tap reducing plug on a 12 kV circuit and causing an arc.	CLOSED
20130501-02	PG&E	Outage attracted media attention	Underground connector	An underground connector failed resulting in an outage to over 3,000 customers.	CLOSED
20130501-04	PG&E	Damage claim	Overhead 12 kV conductor	An oak tree failed below ground level due to catastrophic root failure and fell into a 12 kV circuit in the city of Calistoga.	CLOSED
20130505-01	PG&E	Injury	Underground ground wire	An arc flash occurred while PG&E employees were in the process of removing installed grounds from an underground transformer enclosure in the City of San Francisco. An employee suffered burns to his hands and face from the arc flash and was transported to a hospital in San Francisco.	CLOSED
20130602-01	PG&E	Outage attracted media attention	Underground splice	An outage occurred to 9,100 customers on a 21 kV circuit due to a failed underground splice in the City of Danville.	CLOSED

20130602-02	SCE	Damage claim	Seventy-five poles	A fire consumed approximately 75 SCE poles. The fire was ignited as a result of LADWP electrical facilities in the area.	CLOSED
20130602-03	PG&E	Outage attracted media attention	Switch	An outage occurred affecting 3,558 customers on a 12 kV circuit due to a failed switch in the city of Davis.	CLOSED
20130604-01	PG&E	Outage attracted media attention	Circuit Breaker	A circuit breaker at a substation unexpectedly opened for unknown reasons. The event resulted in an outage to almost 10,000 customers.	CLOSED
20130610-01	SCE	Injury	Underground equipment	Three electrical workers with an SCE contractor were working inside a vault when one of the workers removed an energized component and an arc flash occurred. Two of the three workers were injured as a result.	CLOSED
20130618-01	PG&E	Outage attracted media attention	Two poles	Two poles caught fire due to two separate electric flashovers. The first flashover and resulting fire caused an outage to over 2,000 customers. To perform the required repairs on the second pole, the circuit was de-energized leaving a total of 5,000 customers without power.	CLOSED
20130618-02	PG&E	Outage attracted media attention	Overhead 12 kV insulator	A pole fire was caused by high humidity conditions initiating an arc across one or more insulators. As a result of the fire 1,774 customers were out of power and an additional 174 customers were intentionally disconnected to safely perform restoration procedures.	CLOSED
20130618-03	PG&E	Outage attracted media attention	Overhead 12 kV conductor	An outage occurred on a 12 kV circuit due to a failed cable in the City of Berkeley.	CLOSED
20130620-01	PG&E	Injury	Overhead 12 kV conductor	A third party was injured when a conductor fell on his hand as he was grasping a wooden fence at his residence.	CLOSED
20130623-01	PG&E	Outage attracted media attention	Substation	A series of outages occurred to 149,013 customers in the San Luis Obispo area due to multiple arc-flash events at a substation.	CLOSED
20130623-02	PG&E	Injury	Overhead 12 kV conductor	A parachutist contacted a conductor on a 12 kV circuit during a jump.	CLOSED
20130718-01	PG&E	Outage attracted media attention	Overhead 12 kV conductors	Two spans of primary conductors failed causing an outage to 82 customers.	CLOSED
20130803-02	PG&E	Injury	Power plant	A member of the public watching demolition of the power plant was injured when shrapnel from a boiler implosion struck his leg.	CLOSED
20130815-01	SCE	Damage claim	Overhead jumper wire	One SCE overhead jumper wire and two SCE overhead conductors failed. The overhead conductors fell to the ground and ignited a fire.	CLOSED
20130817-01	PG&E	Outage attracted media attention	Switch	An improperly set switch caused an outage to almost 5,000 customers.	CLOSED

attention

20130930-01	SCE	Fatality	Underground elbow	A subcontractor was fatally injured when he inadvertently removed an energized dead-break elbow while working in an underground vault in Huntington Beach.	OPEN
20131006-01	SDG&E	Media attention due to fire	Overhead secondary	A secondary service wire supplying a signal light and a San Diego Trolley Service crossing arm apparatus separated and fell to the ground causing a small brush fire.	CLOSED
20131006-03	PG&E	Outage attracted media attention	Overhead splice	An automatic splice failed and dropped the middle phase conductor to the ground causing an outage to 5,590 customers in Arroyo Grande.	CLOSED
20131009-01	PG&E	Injury	Meter base	A PG&E contractor was injured by an arc flash while attempting to install a glass meter cover on an energized 480 V meter base.	CLOSED
20131019-01	SCE	Damage claim	Underground 12 kV cable	An underground cable of a 12 kV circuit failed, causing the circuit to relay and lockout. Subsequently, a fire was reported at a bank that caused \$2,000,000 in damages.	CLOSED
20131019-02	PG&E	Damage claim	Substation	A shooting occurred at a substation. Suspects vandalized facilities with several bullet rounds damaging transformers, a circuit breaker, a capacitor bank, and control equipment.	CLOSED
20131021-02	PG&E	Fatality	Overhead 12 kV conductor	A third party fatally contacted a 12 kV overhead circuit while he was in the process of raising a flagpole at a flea market in the city of Fresno.	CLOSED
20131107-01	SDG&E	Damage claim	Underground 12 kV cable	An SDG&E contractor struck and damaged a 12 kV primary underground cable and duct owned by SDG&E while attempting to install ground rods for the ground grid as part of a SDG&E substation expansion project.	CLOSED
20131107-02	PG&E	Outage attracted media attention	Overhead 21 kV conductors	An outage occurred on a 21 kV circuit in the City of Watsonville.	CLOSED
20131111-01	PG&E	Outage attracted media attention	Overhead splice	An outage occurred on a 12 kV circuit due to a failed splice.	CLOSED
20131112-02	PG&E	Outage attracted media attention	Substation	A transmission level outage occurred in the greater Stockton area.	CLOSED
20131114-01	PG&E	Outage attracted media attention	Overhead 12 kV conductors	An outage occurred on a 12 kV circuit affecting 3,653 customers.	CLOSED
20131115-01	PG&E	Injury	Power plant	A PG&E worker injured his leg while riding a tram transporting him from the powerhouse.	CLOSED
20131118-01	PG&E	Outage attracted media	Overhead 4 kV conductor	An outage occurred to 3,312 customers after a Mylar balloon came into contact with overhead conductors.	CLOSED

attention

20131120-01	PG&E	Media attention	Underground secondary	Secondary cable overheated and melted for unknown reasons.	CLOSED
20131122-01	PG&E	Damage claim	Transmission 115 kV lines	Three transmission lines relayed at a switchyard without interruption to customers.	CLOSED
20131125-01	PG&E	Outage attracted media attention	Underground splice	An outage occurred on a 12 kV circuit due to a failed splice.	CLOSED
20131125-02	PG&E	Media attention	Transmission 115 kV line	One phase of a transmission line separated at mid span between two towers.	CLOSED
20131125-04	PG&E	Outage attracted media attention	Overhead parallel groove connector	An overhead parallel groove connector failed and dropped a conductor to the ground. The downed conductor caused an outage to about 3,500 customers.	CLOSED
20131127-01	PG&E	Outage attracted media attention	Transformer	An outage occurred on PG&E circuit due to animal intrusion.	CLOSED
20131203-01	PG&E	Outage attracted media attention	Switch	An outage occurred on a 12 kV overhead circuit due to a manual switching error.	CLOSED
20131205-01	PG&E	Outage attracted media attention	Overhead dead-end shoe (clamp)	An outage occurred on a 12 kV circuit and a 4 kV circuit due to a failed overhead "dead end shoe".	CLOSED
20131206-01	PG&E	Outage attracted media attention	Transformer	A PG&E transformer and switches failed. A total of 5,132 customers were out of power as a result of the failure.	CLOSED
20131208-01	PG&E	Injury	Transformer	A PG&E employee was injured while troubleshooting a transformer after a related outage occurred.	CLOSED
20131210-01	SCE	Media attention due to fire	Overhead 16 kV conductor	SCE personnel driving nearby witnessed a flash on a 16 kV circuit.	CLOSED
20131210-02	PG&E	Outage attracted media attention	Overhead 12 kV conductors	An unexpected fault occurred at an unknown location and caused an outage for 2,550 customers on a 12kV circuit.	CLOSED
20131212-01	PG&E	Outage attracted media attention	Substation	An outage occurred at a substation in the city of Anderson affecting 3,734 customers.	CLOSED
20131213-01	PG&E	Media	Transformer	A station service transformer catastrophically failed at a substation	CLOSED
20131215-01	PG&E	Damage claim	Third-party electrical line	A fire started near the Pfeiffer Ridge in Los Padres National Forest, Big Sur. The incident resulted in a outage to 106 customers and replacement of PG&E facilities.	CLOSED
20131219-01	PG&E	Outage attracted media	Transmission 115 kV line	A 115 kV line and a 70 kV line experienced a sustained outage causing an outage to 26,379 customers.	CLOSED

attention

20131219-02	PG&E	Outage attracted media attention	Transformer	A transformer failed resulting in an outage to 6,127 customers on two circuits.	CLOSED
20131220-01	PG&E	Outage attracted media attention	Overhead 12 kV conductor	An outage occurred to 1,514 customers on a 12 kV circuit due to a bird contact.	CLOSED
20131221-01	PG&E	Outage attracted media attention	Four underground cables	An outage occurred on a 12kV circuit resulting in 125 customers without power. A total of four underground cable failures caused the outage.	CLOSED
20131223-01	PG&E	Outage attracted media attention	Underground cable	A PG&E underground cable failed and caused an outage to 1,960 customers. The type of cable that failed was paper insulated lead cables.	CLOSED
20131225-02	SCE	Outage attracted media attention	Overhead 16 kV conductors	The Simi Valley area experienced high wind conditions resulting in the issuance of red flag warnings. Two 16 kV circuit relayed due to the high wind conditions and caused outages.	CLOSED
20131227-01	PG&E	Outage attracted media attention	Switch	A squirrel caused a phase to ground fault at the Rossmoor Substation. The fault affected 11,561 customers.	CLOSED
20140103-01	PG&E	Outage attracted media attention	Underground splice	An underground splice failed resulting in an outage for 1,395 customers.	CLOSED
20140107-01	PG&E	Outage attracted media attention	Two 12 kV conductors	A substation relay registered a phase to phase fault and opened a circuit breaker protecting a 12 kV circuit. As a result, 4,982 customers were out of power for almost two hours.	CLOSED
20140108-01	PG&E	Outage attracted media attention	Switch	An animal caused an arc on air switch at a substation resulting in an outage to 22,967 customers.	CLOSED
20140111-01	PG&E	Outage attracted media attention	Overhead 12 kV conductor	An outage occurred on a 12 kV circuit due to a separated overhead primary phase.	CLOSED
20140111-02	SDG&E	Injury	Power plant	An SDG&E employee fell through a hatch and sustained a hip injury.	CLOSED
20140114-01	PG&E	Outage attracted media attention	Three overhead 12 kV conductors	An outage occurred on a 12 kV circuit due to all three conductors separating.	CLOSED
20140128-01	PG&E	Damage claim	Switch	An outage occurred on a 21 kV circuit due to a flashed air switch during a manual switching operation.	CLOSED
20140207-01	PG&E	Damage claim	Lightning arrester	A residential structure fire occurred on property located in the town of Twain in Plumas County.	CLOSED

20140217-02	PG&E	Outage attracted media attention	Elbow connector	An outage occurred to 1,366 customers on a 12 kV circuit due to a failed elbow in a vault in the city of Chico.	CLOSED
20140220-01	PG&E	Injury	Overhead 12 kV conductor	A third party operated a forklift into an overhead PG&E conductor and received electrical burns.	CLOSED
20140223-01	PG&E	Outage attracted media attention	Underground 12 kV cable	An underground cable failed on a 12 kV circuit resulting in an outage for 6,687 customers.	CLOSED
20140224-01	PG&E	Outage attracted media attention	Underground connector	An underground connector failed on a 21 kV circuit resulting in an outage for 4,623 customers.	CLOSED
20140226-01	PG&E	Outage attracted media attention	Underground 12 kV cable	An underground cable failed on a 12 kV circuit resulting in an outage for 6,139 customers.	CLOSED
20140301-01	PG&E	Outage attracted media attention	Overhead 12 kV conductor	An outage occurred on a PG&E circuit as a result of a faulty direct current supply conductor connected to a circuit breaker.	CLOSED
20140301-02	SCE	Damage claim	Three overhead 16 kV conductors	During a rainstorm, a helium balloon made contact with three conductors of different phases. Tracking occurred across the helium balloon, resulting in a phase-to-phase fault. This fault condition caused all conductors to separate and fall, causing damage to structures and a truck.	CLOSED
20140303-02	SCE	Outage attracted media attention	Three overhead 16 kV conductors	A eucalyptus tree fell across SCE primary overhead conductors. Shortly thereafter, a fire started in a nearby structure.	CLOSED
20140303-03	PG&E	Injury	Pole	A vehicle hit a pole in the town of Carruthers, Fresno County. The incident resulted in the pole and a conductor on a 12 kV circuit to fall onto the ground. The third party exited his vehicle and he contacted an energized down conductor and was injured.	CLOSED
20140304-01	PG&E	Outage attracted media attention	Underground splice	An underground splice failed on a 12 kV circuit resulting in an outage for 2,304 customers.	CLOSED
20140310-01	PG&E	Outage attracted media attention	Transformer	The tertiary bushing on a bank (115/60 kV) failed at a substation, and the transformer bank relayed. This resulted in an outage to 7,127 customers.	CLOSED
20140310-02	BVES	Major outage	Capacitor bank	A capacitor bank at a substation caught on fire. This interrupted a 34.5 kV line that fed Bear Valley Electric Service's entire service territory.	CLOSED
20140311-01	PG&E	Injury	Overhead 12 kV conductor	A third party was operating a water well drilling rig when one of the lines he pulled made contact with a PG&E 12 kV overhead conductor.	CLOSED
20140314-02	PG&E	Outage attracted	Disconnect	An outage occurred on a 12 kV circuit due to a failed solid blade disconnect.	CLOSED

		media attention			
20140319-02	PG&E	Outage attracted media attention	Two overhead 12 kV conductors	An outage occurred on a 12 kV circuit due to a squirrel contact.	CLOSED
20140327-01	SDG&E	Damage claim	Reactor bank	The windings of a metalclad 12 kV reactor bank in a substation faulted. The fault caused a small fire which burned all the windings within the 12 kV reactor bank metalclad enclosure.	CLOSED
20140328-01	SCE	Injury	Fuse	A SCE lineman was working in an elevated position in a bucket truck when he inadvertently contacted energized fuse holders and sustained burn injuries.	CLOSED
20140329-01	PG&E	Outage attracted media attention	Overhead service	A tree uprooted due to stormy weather conditions and fell on a customer's service line. The customer's weather head was damaged in the incident and required a home electrician to make appropriate repairs.	CLOSED
20140331-01	PG&E	Outage attracted media attention	Fourteen transformers	Lightning strikes in the area caused outages to 185 customers on a 12kV circuit. Fourteen transformers were damaged during this storm event.	CLOSED
20140402-01	PG&E	Outage attracted media attention	Overhead 12 kV conductors	An outage occurred, affecting 1764 customers on a 12 kV circuit.	CLOSED
20140412-01	PG&E	Outage attracted media attention	Overhead 12 kV conductors	An outage occurred on a 12 kV circuit due to a third party fire.	CLOSED
20140414-01	PG&E	Outage attracted media attention	Underground connector	An outage occurred on a 12 kV circuit due to a failed underground 600 amp elbow.	CLOSED
20140418-01	PG&E	Outage attracted media attention	Overhead 4 kV conductors	An outage occurred on a 4 kV circuit due to an uprooted tree.	CLOSED
20140422-01	PG&E	Outage attracted media attention	Overhead splice	A PG&E overhead splice failed dropping the conductor to the ground. A 12 kV circuit opened resulting in an outage to 2,318 customers.	CLOSED
20140429-01	PG&E	Outage attracted media attention	Overhead 12 kV conductors	An outage occurred on a 12 kV circuit due to a Mylar balloon.	CLOSED
20140429-02	SCE	Outage attracted media attention	Overhead 12 kV conductors	A wind gust up to 14 mph caused a large branch in a pine tree in the city of Placentia to break and fall across SCE overhead conductors. The conductors fell, resulting in fire damage to multiple locations in Placentia.	CLOSED
20140429-03	SCE	Outage attracted media attention	Two poles	Two poles failed and fell to the ground.	CLOSED

20140429-04	PG&E	Outage attracted media attention	Underground splice	An outage occurred on a 21 kV circuit due to a failed underground splice.	CLOSED
20140430-02	SCE	Outage attracted media attention	Pole	A pole broke at its ground line and fell to the ground.	CLOSED
20140430-03	SCE	Damage claim	Overhead 12 kV conductors	Strong wind caused three limbs of a large eucalyptus tree to break and fall on overhead electrical facilities on a 12 kV circuit. The contact resulted in a vegetation fire in the city of Hemet.	CLOSED
20140502-01	PG&E	Outage attracted media attention	Overhead splice	A PG&E overhead splice failed and caused a conductor to fall to the ground resulting in an outage to 4,034 customers.	CLOSED
20140504-02	PG&E	Injury	Regulator	A third party contacted a 60 kV regulator inside a substation.	CLOSED
20140511-01	SCE	Injury	Transformer	A SCE 12 kV circuit relayed and locked out. SCE found a pad mounted transformer had been vandalized.	CLOSED
20140513-01	SDG&E	Major outage	Various overhead facilities	High winds reaching gusts of approximately 90 mph persisted for about three days in San Diego County and resulted in multiple power outages.	CLOSED
20140514-01	PG&E	Outage attracted media attention	Underground switch	An outage occurred on a 21 kV circuit due to a failed underground switch.	CLOSED
20140515-01	SCE	Fatality	Overhead 12 kV conductor	An SCE 12 kV overhead copper conductor broke and fell to the ground. A person contacted the downed conductor and was electrocuted.	OPEN
20140515-02	SCE	Outage attracted media attention	Two overhead 12 kV conductors	A Mylar balloon contacted two overhead conductors resulting in a fault current that caused an overhead conductor to fall to the ground starting fire and causing a commercial building to catch fire.	CLOSED
20140516-01	SCE	Damage claim	Transformer	A 75 kVA transformer in the city of Santa Monica catastrophically failed resulting in a structure fire.	CLOSED
20140516-02	SCE	Injury	Overhead service conductor	A fire destroyed a property and caused nearly \$2,000,000 in damages. The fire may have been caused by arcing of electric service drop wires as a result of abrasion from an adjacent tree.	CLOSED
20140517-01	SCE	Damage claim	Relay	A transformer bank relayed and locked out.	CLOSED
20140523-02	PG&E	Outage attracted media attention	Insulators	A pole top caught fire and fell onto the 4 kV lines below resulting in an outage for 2,041 customers.	CLOSED
20140606-01	PG&E	Outage attracted media attention	Overhead 12 kV conductor	An outage occurred on a 12 kV circuit due to a down conductor.	CLOSED

20140606-02	PG&E	Outage attracted media attention	Transformer	A PG&E employee made a switching error resulting in an outage for 18,348 customers.	CLOSED
20140610-01	PG&E	Damage claim	Transformer	An outage occurred on a 12 kV circuit due to a failed underground transformer.	CLOSED
20140612-01	PG&E	Outage attracted media attention	Overhead recloser	An outage occurred on a 12 kV circuit due to a squirrel contact.	CLOSED
20140612-02	PG&E	Outage attracted media attention	Underground connector	An outage occurred on a 21 kV circuit due to a failed underground connector.	CLOSED
20140612-03	PG&E	Outage attracted media attention	Insulators	A 12 kV was de-energized to repair a pole top that was damaged from a fire.	CLOSED
20140612-04	PG&E	Outage attracted media attention	Overhead recloser	A line recloser on a 21 kV circuit opened resulting in an outage for 1,027 customers.	CLOSED
20140615-01	SCE	Injury	Underground 16 kV cables	A third party sustained electrical burn injuries while attempting to cut into 16 kV underground cables housed in conduit installed on a rise pole.	CLOSED
20140616-02	SCE	Injury	Overhead 16 kV conductor	A third party was on a roof of a partially completed building finishing concrete when he inadvertently contacted an SCE 16 kV overhead conductor with an aluminum tool and was injured.	CLOSED
20140617-01	SCE	Outage attracted media attention	Overhead 12 kV conductors	A report of a brush fire indicated that the fire involved downed power lines, but SCE personnel were unable to locate any downed power lines.	CLOSED
20140627-01	PG&E	Outage attracted media attention	Underground cable	An underground secondary connection failed in the city of Chico resulting in an outage to 50 commercial customers.	CLOSED
20140701-01	PG&E	Outage attracted media attention	Insulators	Two pole fires caused an outage to 5,948 customers on a 12 kV circuit.	CLOSED
20140705-01	PG&E	Fatality	Overhead 12 kV conductor	An overhead conductor fell to the ground in Oakland. Two persons were injured when they made contact with the downed conductor; one of the injuries was fatal.	CLOSED
20140705-02	SCE	Damage claim	Poles	Eighteen SCE poles broke and fell to the ground during moderate wind conditions.	CLOSED
20140708-01	PG&E	Outage attracted media attention	Overhead 4 kV conductor	An outage occurred on a 4 kV circuit due to third-party fireworks.	CLOSED
20140709-02	PG&E	Injury	Overhead 12 kV conductor	A third party was injured when a homemade metal flagpole he set in the city of Marysville contacted PG&E's overhead conductor.	CLOSED

20140710-01	PG&E	Outage attracted media attention	Underground splice	An underground splice failed on a 12 kV circuit resulting in an outage for 1,403 customers.	CLOSED
20140711-01	PG&E	Damage claim	Transformer	An outage occurred to 16 customers on a 12 kV circuit.	CLOSED
20140715-02	PG&E	Outage attracted media attention	Circuit breaker	A PG&E 115 kV line was mistakenly de-energized by PG&E employees. As a result, 26,983 customers were without power for six minutes.	CLOSED
20140716-01	PG&E	Damage claim	Substation	A third party structural fire occurred due to overvoltage from PG&E's facility.	CLOSED
20140717-01	SDG&E	Fatality	Overhead 12 kV conductor	Two workers were on top of scaffolding when one of the workers contacted an overhead SDG&E primary conductor and sustained fatal injuries. The other worker who subsequently attempted to provide assistance received an electrical shock.	CLOSED
20140718-01	PG&E	Injury	Overhead 12 kV conductor	A crop-dusting helicopter struck a PG&E guy wire on a 12 kV circuit and caused an outage.	CLOSED
20140718-02	SCE	Injury	Poles	Two poles installed next to State Route 14 fractured and failed, causing 16 kV overhead conductors to fall on the highway.	CLOSED
20140718-03	PG&E	Outage attracted media attention	Overhead conductors	An outage occurred to the Whitmore and Cedar Creek Substations, affecting 1,326 customers on the Kilarc-Deschutes 60 kV line.	CLOSED
20140719-01	SCE	Outage attracted media attention	Underground 12 kV cable	A 12 kV underground cable faulted and failed inside a trench, resulting in an outage to approximately 1,200 customers.	CLOSED
20140720-01	Liberty	Major outage	Substation bus	A lightning strike caused an outage to several substations. The outage affected approximately 25,000 Liberty Utilities customers.	CLOSED
20140721-01	PG&E	Injury	Fuse	A contractor hired by PG&E to complete a pole replacement was shocked when he made contact with a protection device.	CLOSED
20140722-01	SDG&E	Injury	Overhead 12 kV conductor	An SDG&E contractor was installing a "High Voltage" warning sign on a hollow steel pole that housed three 12 kV cables when he drilled into a 12 kV cable and was injured.	CLOSED
20140722-02	PG&E	Outage attracted media attention	Overhead 12 kV conductor	An outage occurred on a 12 kV circuit due to conductor failure.	CLOSED
20140724-01	SCE	Major outage	Transformer	A winding of a transformer in a substation experienced a phase-to-ground fault and caught on fire. This cause an outage to over 26,800 customers.	CLOSED
20140724-02	PG&E	Outage attracted media attention	Overhead 60 kV conductors	An outage occurred on a 60 kV transmission circuit due to an uprooted tree.	CLOSED

20140727-01	PG&E	Damage claim	Overhead 12 kV conductor	An oak tree in the town of El Portal fell and contacted a conductor. The contact created a fire in which 4,690 acres were burnt and property damage exceeded \$50,000. The fire caused an outage affecting 591 customers.	CLOSED
20140728-01	SCE	Outage attracted media attention	Three overhead 12 kV conductors	A 4 kV overhead insulator failed and caused a ground fault current. This caused multiple connectors to overheat and fail within three conductor spans.	CLOSED
20140730-01	PG&E	Outage attracted media attention	Overhead 4 kV circuit	PG&E de-energized a 4 kV circuit due to a third-party fire.	CLOSED
20140801-01	PP&L	Fatality	Overhead 12 kV conductors	A crop duster flying under 12 kV circuit power lines made contact with 12 kV conductors and crashed.	CLOSED
20140802-02	PG&E	Outage attracted media attention	Four overhead 12 kV conductors	Four spans of PG&E conductor on a 12kV circuit fell to the ground causing an outage to 3,192 customers	CLOSED
20140804-01	SCE	Outage attracted media attention	Underground splice	Insulation on a 16 kV underground circuit failed at a splice located inside a vault and caused an outage.	CLOSED
20140804-02	SCE	Media attention	Pole	A pole fire was reported to SCE by the fire department.	CLOSED
20140804-03	PG&E	Outage attracted media attention	Circuit breaker	A PG&E circuit breaker opened on a 12 kV conductor causing an outage for 3,828 customers.	CLOSED
20140805-01	SCE	Injury	Underground 12 kV cable	A third party inadvertently cut into a 12 kV SCE underground cable and sustained electrical burn injuries while working on a sewer pipe.	CLOSED
20140806-02	PG&E	Injury	Overhead 12 kV conductor	A third party landscaper was trimming a tree when the pruning tool he was using made contact with a PG&E 12 kV overhead conductor.	CLOSED
20140806-03	SCE	Damage claim	Underground cable	An underground SCE secondary neutral cable failed. As a result, residencies experienced floating voltage conditions. One of the residents' power strip failed and ignited a fire.	CLOSED
20140806-05	SCE	Damage claim	Pole	SCE finalized a pole replacement project. After re-energizing the service line, a fire erupted in two residences.	CLOSED
20140810-01	PG&E	Outage attracted media attention	Two overhead 12 kV conductors	3,854 customers experienced an outage on a 12 kV circuit when a line recloser operated in the city of Pleasanton.	CLOSED
20140811-01	SCE	Damage claim	None	There was a structure fire in the city of Grand Terrace. The insurance company stated the damage to the home is approximately \$260,000.	CLOSED
20140812-01	SCE	Injury	Underground 12 kV cable	An SCE contractor sustained electrical burn injuries when he cut into a conduit housing an energized 12 kV circuit.	CLOSED

20140818-01	PG&E	Outage attracted media attention	Three overhead 12 kV conductors	An outage occurred on a 12 kV circuit due to a third-party fire.	CLOSED
20140818-02	SCE	Damage claim	Nineteen poles	Nineteen SCE wood poles of Grade B construction broke and fell to the ground.	CLOSED
20140818-03	SCE	Damage claim	Insulator/overhead 12 kV conductor	An insulator and/or conductor on a 12 kV circuit failed, causing the circuit to relay and lock out. Subsequently, a fire was reported which ultimately consumed 4,045 acres of vegetation, two vehicles, 14 properties, nine SCE poles, and several spans of conductors.	CLOSED
20140819-01	PG&E	Outage attracted media attention	Transformer	An outage occurred on a 12 kV circuit due to a failed overhead transformer.	CLOSED
20140819-02	PG&E	Outage attracted media attention	Overhead conductors	An outage occurred on a PG&E circuit due to a Mylar balloon.	CLOSED
20140822-01	PG&E	Outage attracted media attention	Underground splice	A PG&E underground splice failed on a 12 kV circuit causing an outage to 1,828 customers.	CLOSED
20140824-01	PG&E	Outage	Various facilities	A magnitude 6.0 earthquake occurred in Napa causing outages to 75,509 customers.	CLOSED
20140826-01	SCE	Fatality	Transmission tower	An individual climbed a 105-foot steel lattice transmission tower that supported a 66 kV SCE circuit, and jumped to the ground and committed suicide.	CLOSED
20140827-01	PG&E	Vandalism	Substation	A substation was burglarized by unknown suspects. The suspects breached the fence and stole construction equipment from the staging yard and the substation operations yard. It was reported that approximately \$40,000 in equipment was missing from the substation.	CLOSED
20140829-01	SCE	Injury	Overhead 4 kV conductors	Two firefighters received shock injuries when they inadvertently contacted a downed SCE overhead conductor while extinguishing a fire in El Cerrito (Riverside County).	CLOSED
20140902-01	PG&E	Outage attracted media attention	Underground connector	An underground connector failed on a 12 kV circuit causing an outage to 3,558 customers.	CLOSED
20140904-01	SCE	Damage claim	Overhead conductors	A tree contacted one or more SCE overhead secondary conductors during strong wind conditions resulting in an over-voltage that resulted in a fire at a property which caused over \$50,000 in damages.	CLOSED

20140906-01	SCE	Outage attracted media attention	Pole	An SCE pole broke at approximately 7 feet from the top of the pole. The 7-foot pole segment - supporting SCE 16 kV overhead conductors – fell to the ground, causing the SCE overhead conductors to hang across Pacific Coast Highway.	CLOSED
20140909-01	SDG&E	Damage claim	Capacitor bank	A capacitor bank caught fire in a substation. Smoke from the fire caused soot to build up on two tielines, resulting in a flashover. This tripped a 138 kV bus tie, de-energizing a 138 kV bus and a 128/12 kV transformer.	CLOSED
20140909-02	SCE	Media attention	Overhead conductors	An SCE subcontractor was pulling conductors across two transmission towers. The equipment used to pull the conductor broke causing the equipment and a conductor to fall down across State Route 60 freeway.	CLOSED
20140909-03	SCE	Judgment call	Overhead conductors	An SCE contractor was installing a new conductor using a hoist. The hoist failed and caused a conductor to fall and damage a small agricultural shade shed. Also, an employee of the contractor sustained minor injury to his hand as a result of the incident.	CLOSED
20140912-01	SDG&E	Damage claim	Two poles	Two poles fractured, fell to the ground, and came in contact with a passing vehicle.	CLOSED
20140916-01	PP&L	Damage claim	Various	A large wildfire in Weed damaged Pacific Power facilities.	CLOSED
20140917-01	PG&E	Damage claim	Pole	A semi-truck veered off the road and hit a pole in the city of Orland. This caused conductors to fall to the ground and start a fire that damaged a house near the incident.	CLOSED
20140918-01	PG&E	Outage attracted media attention	Various	A storm resulted in multiple outages in the East Bay.	CLOSED
20140923-01	SCE	Damage claim	Pole	An SCE pole burned, broke near its midpoint, and fell to the ground.	CLOSED
20140924-01	SCE	Injury	Ladder	Two laborers working for an SCE contractor were inside an SCE vault, when a ladder a laborer was using to exit the vault buckled, causing him to fall onto the other laborer, who had been standing below securing the ladder.	CLOSED
20140924-02	PG&E	Judgment call	Overhead 12 kV conductors	Two occupants in a single engine plane flew into a 12 kV circuit causing the conductors to fall to the ground. All 63 customers without power were restored within twelve hours.	CLOSED
20140927-01	PG&E	Injury	Guy wire	A third party made contact with an "energized" guy wire while descending the pole.	CLOSED
20141003-01	SCE	Damage claim	Transformer	A transformer failed inside a substation and caused SCE to utilize load shedding procedures for approximately three hours, affecting approximately 18,000 customers.	CLOSED
20141003-02	PG&E	Outage attracted media attention	Overhead 12 kV conductors	An outage occurred on a 12 kV circuit due to a fallen tree.	CLOSED

20141005-01	PG&E	Injury	Overhead 12 kV conductor	A third party was injured when he lifted a 47 foot antenna onto PG&E's 12 kV conductor in the city of Atwater.	CLOSED
20141009-01	Trans Bay Cable	Damage	Submarine cable	A vessel dropped anchors in the Carquinez Strait due engine malfunction. The anchors struck and damaged Trans Bay Cable's 200 kV direct current submarine cable.	CLOSED
20141018-01	PG&E	Injury	Overhead 12 kV conductor	A PG&E lineman was injured while installing an overhead conductor.	CLOSED
20141022-01	SCE	Outage attracted media attention	Transformer	Transformers failed after SCE crew completed a planned maintenance work involving replacement of a gas switch of a 16 kV circuit in an underground vault.	CLOSED
20141027-01	SCE	Fatality	Transmission tower	The Sheriff's Department received a 911 call from an individual threatening to jump from a tower. That same day, a body was discovered near the base of an SCE transmission tower, which was under construction.	CLOSED
20141106-01	SCE	Injury	Underground elbow	Two SCE workers sustained electrical burn injuries when they removed a dummy elbow from an energized, 12 kV switch inside a vault.	CLOSED
20141109-01	PG&E	Fatality	Overhead conductors	An aircraft collided with a 21 kV circuit and caused an outage.	CLOSED
20141112-01	PG&E	Injury	Underground 21 kV cable	San Jose city employee was replacing a sewer line when he hit and damaged a PG&E 21 kV underground conductor. As a result, he received burn injuries to his face and arms.	CLOSED
20141125-01	SDG&E	Intentional outage - response to Red Flag Warning	Transmission circuit	In response to a Red Flag Warning issued by the National Weather Service in San Diego and Orange counties, SDG&E proactively de-energized two distribution circuits and one transmission circuit.	CLOSED
20141125-02	SCE	Fatality	Overhead 16 kV conductor	A tree trimmer was trimming a tree when he inadvertently contacted an SCE overhead conductor with an aluminum pruning pole and was fatally injured.	CLOSED
20141205-01	PP&L	Outage	Overhead conductors	A Pacific Coast storm affected electric reliability across the north coast of California. The heavy rain and high winds cause large numbers of trees to become unstable and fall onto transmission and distribution power lines.	CLOSED
20141207-01	SCE	Injury	Two underground 12 kV cables	Two SCE contractors were chipping concrete in a concrete duct adjacent to an SCE vault when they inadvertently struck two energized SCE 12 kV cables, resulting in arc burn injuries.	CLOSED
20141208-01	TBC	Judgment	Phase arm	An outage occurred at a converter station due to excessive corona.	CLOSED
20141210-01	PP&L	Injury	Overhead 12 kV conductor	A third party was injured when he lifted an irrigation pipe into a 12 kV overhead conductor. He sustained burn injuries to his right shoulder and feet.	CLOSED
20141211-01	PG&E	Outage attracted media	Underground 12 kV cable	An underground cable failed in the City of San Francisco and caused an outage to 86,000 customers.	CLOSED

attention

20141215-01	PG&E	Outage attracted media attention	Two poles	An outage occurred on a 21 kV circuit due to a storm.	CLOSED
20141219-01	PG&E	Outage attracted media attention	Underground splice	A PG&E underground splice on a 12 kV circuit failed causing an outage for 38 customers.	CLOSED
20141222-01	SCE	Outage	Circuit breaker	A 66 kV circuit breaker failed and caught on fire at a substation. The event caused an outage to approximately 20,000 customers for approximately four hours.	CLOSED
20141227-01	SDG&E	Outage	Underground connector	A T-body connector inside a manhole failed, causing an outage.	CLOSED
20141230-01	PG&E	Fatality	Overhead conductors	A metallic truck bed made contact with an overhead PG&E circuit. While the bed was in contact with the energized conductor, the driver stepped out onto the ground and was electrocuted.	CLOSED
20150103-01	PG&E	Media attention due to plane crash into overhead circuit	Overhead 12 kV circuit	An airplane struck a 12 kV circuit and caused an outage to 155 customers.	CLOSED
20150105-01	SDG&E	Damage claim	Overhead transformer	An overhead distribution transformer failed, causing an overvoltage condition on the secondary conductors servicing an adjacent residence. Subsequently, a fire occurred inside the residence that resulted in nearly \$100,000 of damages.	CLOSED
20150106-01	PG&E	Fatality	Overhead 60 kV conductor	A third-party contractor was fatally injured while operating a bucket lift that either made contact or received an arc flash from a 60 kV conductor.	CLOSED
20150108-08	PG&E	Outage attracted media attention	Underground 12 kV conductor	A third party dug into a underground 12 kV conductor. The dig-in caused a fire and an outage on the 12 kV circuit.	CLOSED
20150120-01	PG&E	Outage attracted media attention	Circuit breaker	Two PG&E electricians were conducting a test of substation equipment in a PG&E substation. During the testing procedure, the electricians caused a phase to phase fault inside a circuit breaker.	CLOSED
20150126-01	SCE	Outage attracted media attention	Overhead 12 kV conductor and poles	A eucalyptus tree in the city of Fontana uprooted during a windstorm, fell onto three SCE overhead conductors, and damaged three SCE poles and associated equipment. The subsequent outage affected 1,345 customers for approximately 11 hours.	CLOSED

20150204-01	SDG&E	Outage attracted media attention	Splice	During underground work in Balboa Park, SDG&E personnel inadvertently moved an underground primary cable, damaging an aged hand splice connection at the end of the line. The subsequent interruption affected seven customers for approximately 13 hours and 30 minutes.	CLOSED
20150206-01	SCE	Damage	12 kV circuit	SCE received reports of a brush fire which started in Bishop, Inyo County and may have involved its facilities.	OPEN
20150207-01	SCE	Damage	Pole, 16 kV circuit and substation equipment	A fire burned approximately 509 acres in Mono County and damaged seven poles that supported two 16 kV circuits, and facilities inside a substation.	CLOSED
20150210-01	PG&E	Damage (Incident occurred on 2/21/2013, but PG&E was not aware of the damage until 2/10/2015)	Transformer	While replacing a transformer, a fault occurred killing about 39,000 lbs. of Rainbow Trout in their pond system. The cost of lost fish inventory is in excess of the \$50,000 criterion.	OPEN
20150213-01	SCE	Injury	Overhead 16 kV conductor	A third party was moving a ladder when the ladder contacted an energized SCE overhead conductor resulting in burn injuries to the third party..	CLOSED
20150224-01	SCE	Injury	Fuse holder	A contractor worker was ascending a pole when he inadvertently contacted an energized fuse holder.	CLOSED
20150226-01	PG&E	Outage attracted media attention	60 kV circuit	A 60 kV line experience a fault causing an outage to one major customer (City of Healdsburg).	CLOSED
20150227-01	PG&E	Injury	Overhead 12 kV conductor	A crop dusting helicopter struck 12 kV distribution conductors in a tangerine orchard in Visalia, causing an outage to a customer on that circuit, and injuring the pilot.	CLOSED
20150228-01	SCE	Injury	Overhead 66 kV conductor	A person climbed an SCE steel lattice pole and made contact with a 66 kV overhead conductor.	CLOSED
20150303-01	SCE	Injury	Pole replacement equipment	A lineman sustained injury to the left hand fingers while replacing a pole.	CLOSED
20150318-01	SCE	Injury	Pole and 12 kV conductor	A laborer was operating a forklift when he inadvertently struck an SCE pole with the forklift, causing the pole and associated overhead conductors to fall to the ground. He suffered second degree burns as a result of electrical contact.	CLOSED
20150325-01	SDG&E	Damage	Underground 12 kV conductor	A sub-contracting excavator struck a 12 kV underground cable, resulting in an outage to 24 customers and damages to SDG&E facilities in excess of \$50,000.	CLOSED
20150325-02	SCE	Outage attracted media attention	16 kV circuit	A 16 kV circuit relayed and locked out causing outages.	CLOSED

20150325-04	PG&E	Fatality	12 kV circuit	A third party fatality due to electrical contact and reported outage to 50 customers on a 12 kV circuit in Fresno.	OPEN
20150329-01	SCE	Fatality and injury	16 kV connector	Three lineman contractors were reportedly injured as they were finishing a planned outage in Hermosa Beach, Los Angeles County.	OPEN
20150403-01	SCE	Damage	Underground secondary cable	A residential unit sustained fire damage due to the failure of insulation on an underground secondary neutral cable.	CLOSED
20150406-01	PG&E	Outage attracted media attention	Substation	A sustained outage affecting approximately 74,000 customers in the Chico area occurred.	OPEN
20150409-01	SDG&E	Injury	Tree during tree trimming	A tree trimmer was trapped under dead fronds of a palm tree, and stayed overnight at a hospital for observation.	CLOSED
20150409-02	PG&E	Injury	Overhead 115 kV conductor	A transmission lineman sustained non life threatening injury after contacting a 115 kV conductor in the city of Newark.	OPEN
20150410-01	PG&E	Fatality and injury	Padmounted transformer	One person was electrocuted and one was injured when they attempted to open and vandalize a PG&E pad-mount transformer in an underground line section of a 12 kV circuit in the city of Stockton.	OPEN
20150413-01	SDG&E	Outage attracted media attention	Lightning arrester	A lightning arrester failed on a pole, causing a 275 acre fire on Camp Pendleton.	CLOSED
20150414-01	SCE	Injury	Equipment in underground vault	A 16 kV distribution circuit relayed and reclosed. SCE subsequently received a report that two contractor linemen were injured while working in a vault and transported to a hospital.	OPEN
20150422-01	SCE	Fatality	Transmission tower	The police department received notification of a body located on the ground in close proximity to a transmission tower.	OPEN
20150504-01	SCE	Fatality	Transmission tower	A third party climbed a 90-foot steel pole jointly used by SCE and LADWP, contacted an LADWP 34.5 kV overhead conductor, and fell to the ground. He received fatal injuries.	CLOSED
20150506-01	PG&E	Outage attracted media attention	Pole-mounted transformer	A Mylar balloon came into contact with a pole-mounted 12 kV transformer in San Leandro. The incident caused an outage to customers on the 12 kV circuit.	CLOSED
20150507-01	PG&E	Injury	Pole	A PG&E lineman was injured (broken leg) while removing a pole on a PG&E job site.	OPEN

20150514-01	PG&E	Outage attracted media attention	50 kVA transformer	Lightning struck a flag pole and arced from the flag pole to a customer's service drop causing a voltage surge leading to equipment failure. The incident resulted in an outage to customers.	CLOSED
20150518-01	PG&E	Outage attracted media attention	Overhead 12 kV conductor	A Mylar balloon came into contact with a 12 kV circuit causing an outage to customers.	CLOSED
20150519-01	SCE	Damage	16 kV circuit	A residential fire caused nearly \$100,000 in property damage.	CLOSED
20150523-01	SCE	Injury	Overhead 12 kV conductor	A hang glider was injured when he contacted SCE overhead conductors, causing a 12 kV circuit to relay and lock out.	CLOSED
20150528-01	PG&E	Outage attracted media attention	Lightning arrester	A lightning arrester mounted on a self-protected transformer broke from its mount and came in contact with the transformer casing. The incident resulted in an outage to two customers.	CLOSED
20150601-01	PG&E	Injury (incident occurred on 5/22/2015, PG&E was not aware of it until 6/1/2015)	12 kV circuit	PG&E was notified by OSHA of an injury based on a report filed by an injured third party's employer. A boom made contact with an overhead conductor while moving pipes causing the injury to one person.	OPEN
20150604-01	SDG&E	Outage attracted media attention	4 kV circuit	A eucalyptus tree fell on a 4 kV circuit causing an outage.	CLOSED
20150606-01	PG&E	Fatality	Overhead 12 kV conductor	A third party was using a crane to install a new well pump motor, when the cables used to raise the crane contacted a PG&E overhead conductor.	CLOSED
20150608-01	SDG&E	Outage attracted media attention	230 kV circuit	A 230 kV transmission circuit experienced voltage fluctuations. This affected approximately 125,000 customers for about three hours, and resulted in flickering lights, and damage to electronic appliances that totaled approximately \$12,000.	CLOSED
20150609-01	SDG&E	Media attention due to fire	69 kV conductors	A hawk made contact with 69 kV overhead conductors starting a fire.	CLOSED
20150609-02	PG&E	Damage	Pole and 12 kV conductor	A pole and wire fell on a house in the City of Traver and caused total loss of the house.	OPEN
20150610-01	SDG&E	Injury	138 kV circuit	A contractor was injured while working on an overhead circuit.	OPEN
20150613-01	BVES	Outage	Lightning strike affecting overhead equipment	Bear Valley Electrical Service (BVES) experienced a system-wide outage.	CLOSED
20150613-02	BVES	Outage	Lightning strike affecting overhead equipment	Bear Valley Electrical Service (BVES) experienced a system-wide outage for 20 minutes.	CLOSED
20150621-01	SCE	Injury	12 kV primary riser	One person was injured while attempting to vandalize a 12 kV primary riser, causing a small pole fire.	CLOSED

20150623-01	PG&E	Outage attracted media attention	Pole	A third party excavator struck a distribution pole and telephone span guy which caused the primary overhead conductor to break and fall to the ground in the City of Arvin. The incident resulted in an outage affecting 102 customers.	CLOSED
20150624-01	SCE	Injury	16 kV circuit	A third party was injured when the tool he was using to chip encasement on a duct made contact with an underground 16 kV cable.	OPEN
20150625-01	PG&E	Media attention due to public transit delays and fire	Overhead connector	A fault occurred on a distribution circuit causing a connector to fail. The failure caused conductors to fall onto the ground and across Bay Area Rapid Transit (BART) tracks resulting in a grass fire.	CLOSED
20150626-01	SCE	Injury	Fiberglass insulator	A sub-contractor sustained a head injury while digging a hole to replace a pole, from a falling fiberglass insulator that had been loosely hung on an aerial bucket truck.	CLOSED
20150703-01	SDG&E	Outage attracted media attention	12 kV circuit	SDG&E experienced a circuit outage affecting 6288 customers for approximately fifteen hours.	CLOSED
20150703-02	SCE	Media attention due to brush fire	Overhead 12 kV conductor	A pine tree located adjacent to a span of 12 kV overhead conductors fell onto a eucalyptus tree, which in turn contacted the 12 kV conductors, causing a fault, and fell to the ground.	CLOSED
20150707-01	PG&E	Injury	Overhead 12 kV conductor	A worker made contact with an overhead conductor while on scaffolding.	OPEN
20150709-01	SCE	Injury	Overhead 12 kV conductor	A contractor working on a pole replacement project made contact with overhead facilities and sustained flash burns to his face.	OPEN
20150709-02	SCE	Damage	Underground 66 kV cable	A third party contractor, while performing directional boring for the installation of gas facilities, struck and damaged unmarked 66 kV underground sub-transmission cables.	CLOSED
20150713-01	SDG&E	Outage attracted media attention	Overhead switch	An overhead switch failed and caused an outage to 1700 customers.	OPEN
20150713-02	SDG&E	Outage attracted media attention	Underground connector	An underground connector failed and caused an outage to 2855 customers.	CLOSED
20150713-03	SDG&E	Outage attracted media attention	Underground connector	An underground connector failed causing outages.	OPEN
20150714-01	SCE	Damage (incident occurred on 10/12/2012; however, SCE was not aware of the damages until 7/14/2015)	Transformer	SCE received a summons indicating that lightning struck a transformer which serves a residence and caused \$424,957.68 in damages.	OPEN

20150715-01	SCE	Media attention due to fire	12 kV circuit	News media reported a vault fire and interruption of electrical service to customers in the Long Beach area.	OPEN
20150719-01	SCE	Media attention due to outage and fire	Overhead 12 kV conductor	A high wind event caused damage to overhead electrical facilities on a 12 kV circuit which relayed and locked-out. Six poles sustained damage resulting in downed conductors and the closure of Highway 74 by the California Highway Patrol.	OPEN
20150720-01	SCE	Media attention due to outage and fire	16 kV circuit	A 16 kV circuit relayed and locked-out. SCE subsequently received notification of a vault fire in the city of Val Verde.	CLOSED
20150727-01	PG&E	Fatality	Overhead 21 kV conductor	A tree trimmer was electrocuted when he contacted a 21 KV line.	CLOSED
20150727-02	PG&E	Damage	Overhead 115 kV circuit	An airplane struck PG&E's facility causing damage over \$50,000.	CLOSED
20150730-01	PG&E	Injury	Overhead 12 kV conductor	PG&E received report of a third party injury caused by contact with an overhead conductor through a metal object in the city of Paso Robles.	CLOSED
20150730-02	PG&E	Damage	Transformer	A house in the city of Dixon caught fire. Preliminary reports indicate that the fire may have started at a failed transformer on a 12 kV circuit near the house.	OPEN
20150731-01	PG&E	Damage	Overhead connector	An overhead connector failed and caused damage to a property exceeding \$50,000.	CLOSED
20150801-01	SCE	Injury	Overhead 12 kV conductor	Two individuals riding motorcycles contacted overhead electrical facilities and sustained injuries.	OPEN
20150812-01	SCE	Damage	Underground secondary cable	An excavator struck an underground secondary cable. Shortly after the cable was struck, a fire erupted at a nearby house.	OPEN
20150813-01	PG&E	Injury	Substation	A third party entered a substation and made contact with energized facilities.	OPEN
20150814-01	PG&E	Media attention due to third party contact	Overhead 115 kV conductor	A third-party operated crane contacted a 115 kV conductor.	CLOSED
20150815-01	PG&E	Injury	Overhead 12 kV conductor	A third party cut a PG&E distribution pole and caused a 12 kV circuit to fall down. The third party made contact with the circuit while trying to exit the tractor.	CLOSED
20150821-01	SCE	Damage	Poles	A fire started in the San Gabriel Canyon area of Los Angeles County and damaged 30 poles belonging to SCE.	OPEN
20150823-01	SCE	Damage	Poles	A fire broke out in the Whittier Narrows area in Montebello damaging SCE overhead facilities.	OPEN
20150828-01	SCE	Injury	138 kV tieline	An SDG&E employee was injured working overhead.	OPEN

20150828-02	PG&E	Media attention	Transmission tower	A crane hit a transmission tower causing the tower to collapse and wires to come down in Burlingame.	OPEN
20150902-01	PG&E	Damage	Unknown	PG&E was put on notice by Walmart in the City of Anderson that they sustained damages in excess of \$50,000 from a voltage incident on August 17, 2015.	OPEN
20150914-01	SCE	Damage	Secondary service	SCE received correspondence from a insurance company claiming property damage in excess of \$50,000 as a result of fluctuating voltage to a home in Manhattan Beach, Los Angeles County.	OPEN
20150915-01	SCE	Outage	Substation bus	An operating bus at a substation relayed to lockout affecting five circuits totaling 9,172 customers. Another operating bus relayed to lockout affecting six circuits affecting an additional 13,485 customers.	OPEN
20150916-01	PG&E	Fatality	Overhead 12 kV conductor	A tree may have contacted a PG&E line in Butte, causing a fire that resulted in two fatalities.	OPEN
20150916-02	SCE	Outage attracted media attention	Customer primary meter	A customer-owned primary meter failed and caused SCE's 12 kV distribution circuit to relay and lock out.	OPEN
20150920-02	SCE	Outage attracted media attention	16 kV circuit	A downed conductor caused a 16 kV distribution circuit to relay and lock out causing an outage.	OPEN
20150921-01	SCE	Outage attracted media attention	Pole-mounted transformer	A transformer failure on a pole caused an outage and a fire in a palm tree.	OPEN
20150923-01	SDG&E	Damage	69 kV Conductor	A 69 kV overhead conductor fell onto a 4 kV conductor and trolley catenary conductor.	CLOSED
20150925-01	PG&E	Fatality	Padmounted transformer	An individual sustained fatal injuries while attempting to vandalize a pad mounted transformer.	CLOSED
20150925-02	SCE	Fatality	Padmounted transformer	An individual sustained fatal injuries while attempting to vandalize a pad mounted transformer.	OPEN
20150926-01	PG&E	Injury	Subsurface transformer	An outage occurred on a 12 kV circuit in San Francisco. During the restoration process, an underground PG&E transformer catastrophically failed resulting in injury to two nearby individuals.	OPEN
20150930-01	SCE	Outage	Overhead insulator	A flashover on an insulator supporting a 115 kV transmission line resulted in an outage to over 40,000 customers.	CLOSED
20150930-02	PG&E	Fatality	Pole	A PG&E employee was utilizing rigging while preparing to replace a pole when a pulley failed and struck the employee resulting in his fatal injury..	CLOSED
20151001-01	SCE	Outage	12 kV circuit	Two 12 kV circuits caused an outage to approximately 3,500 customers in the City of Fountain Valley and 35,988 in the City of Huntington Beach.	OPEN

20151002-01	PG&E	Injury	230 kV conductors	A contractor received an induction shock at a structure on a 230 kV transmission line while working on overhead facilities.	OPEN
20151005-01	SCE	Injury	Manhole	A woman slipped and fell into an open manhole when she approached SCE contractors, who were engaged in performing underground maintenance and repair work in the manhole.	OPEN
20151005-02	SCE	Injury	Underground 12 kV conductor	A construction worker dug up and contacted an underground cable section of a 12 kV distribution line.	OPEN
20151013-01	BVES	Outage attracted media attention	34 kV circuit	A tree branch made contact with 34 kV overhead lines causing an outage to approximately 9,200 customers in the city of Big Bear.	OPEN
20151018-01	PG&E	Judgment	230 kV conductors	A tower supporting two 230 kV lines failed resulting in the conductors falling across two 115 kV lines, affecting approximately 55,000 customers.	OPEN
20151019-01	PG&E	Injury	500 kV circuit	A PG&E lineman received electrical burns on his wrists and feet while working on overhead facilities.	OPEN
20151026-01	SCE	Outage attracted media attention	Overhead 4 kV circuit	A 4 kV circuit relayed as a result of a drone flying into the power lines and caused one of the conductors to fall resulting in an outage.	CLOSED
20151103-01	PG&E	Outage attracted media attention	Poles	A storm related event (heavy rain, wind and lightning) resulted in 8 poles down in Chico and an outage to 7,585 customers.	OPEN
20151104-01	SDG&E	Media attention due to vault explosion	Vault	A San Diego Gas and Electric electrical vault exploded.	OPEN
20151105-01	SCE	Injury	Underground 12 kV conductor	An employee of the City of Tulare Water Department was using a jack-hammer that contacted and damaged underground electrical facilities resulting in burn injuries to both of his hands.	OPEN
20151106-01	PG&E	Damage	Pole	A pole fire occurred during a storm on November 2, 2015.	OPEN
20151107-01	SCE	Media attention due to outage and fire	16 kV circuit	A fire may have been caused by overhead electric facilities.	OPEN
20151114-01	SCE	Injury	12 kV circuit	An individual cut a primary cable conduit that was located under a bridge (vandalism).	CLOSED
20151116-01	PG&E	Outage due to equipment issues	Overhead 12 kV conductor	A primary conductor came down in San Jose on a 12 kV circuit resulting in an outage to 2,156 customers.	CLOSED
20151118-01	SCE	Damage	Bolt connector	A secondary connector may have failed and caused a structure fire.	OPEN
20151120-01	PG&E	Injury due to contact with electrical conductor	230 kV conductors	Two employees of a PG&E contractor were injured while working on overhead facilities.	OPEN

20151122-01	SCE	Injury	Overhead 12 kV conductor	A third party contacted a section of a 12 kV circuit from an elevated position in a bucket truck while trimming trees for the owner of a home in Weldon.	OPEN
20151125-01	SDG&E	Outage attracted media attention	Overhead 12 kV conductor	A big rig truck transporting an oversized load struck SDG&E overhead electrical conductors spanning across Interstate 8 Freeway and caused a power outage.	OPEN
20151128-01	SCE	Injury	Substation	An individual accessed energized equipment within a substation and suffered severe burn injuries.	OPEN
20151208-01	SCE	Media attention due to oil release	Pole replacement equipment	An underground oil pipeline was damaged by a contractor working for SCE during a pole replacement resulting in an oil release.	OPEN
20151209-01	PG&E	Damage	Overhead 12 kV conductor	A truck made contact with an overhead conductor causing the conductor to fall down and resulting in damages to the vehicle in excess of \$50,000.	OPEN
20151210-01	SCE	Damage	Substation transformer	A 220/66kV substation transformer failed at a substation located near Irwindale, Los Angeles County.	OPEN
20151210-02	PG&E	Injury	Overhead 21 kV conductor	PG&E received notice of a third party contact with energized overhead lines in Watsonville.	OPEN
20151211-01	SCE	Injury	12 kV circuit	A contractor working on overhead facilities sustained injuries in a flash event.	OPEN
20151212-01	SCE	Media attention due to outage and fire	16 kV circuit	A brush fire under overhead facilities caused a 16 kV circuit to relay and reclose.	OPEN
20151230-01	SCE	Injury	12 KV circuit - Connector	An SCE employee working on a pole was injured while replacing a connector on a conductor.	OPEN