

SANTA CLARA COUNTY BUILDING INSPECTION OFFICE

TYPICAL RESIDENTIAL INTERCONNECTED STORAGE BATTERY SYSTEM REQUIRED SIGNAGE

SIGNS SHALL BE WEATHERPROOF AND SUITABLE FOR THE ENVIRONMENT THEY ARE INSTALLED
LETTERING SHALL BE A MINIMUM LETTER HEIGHT OF 3/8" PERMANENTLY AFFIXED.

CAUTION STORAGE BATTERY SYSTEM
CONNECTED

Label Main Service: CEC 705.12(D)(4)

WARNING
INVERTER OUTPUT CONNECTION
DO NOT RELOCATE THIS
OVERCURRENT DEVICE

Label on POI breaker if OCPDs exceed 100% of bus rating CEC 705.12 (D) (7)

A PERMANENT PLAQUE OR DIRECTORY, DENOTING
ALL ELECTRIC POWER SOURCES ON OR IN THE
PROMISES SHALL BE INSTALLED AT EACH SERVICE
EQUIPMENT LOCATION AND AT LOCATIONS OF ALL
POWER SOURCES CAPABLE OF BEING
INTERCONNECTED

To be applied at exterior of building in readily visible location.
A directory needs to be installed when utility service disconnect and
PV system disconnect are not in the same location.
Must be at the location of the photovoltaic system disconnecting means.
NEC 705.10