

2018-2019 GENERAL ORDER 165 ANNUAL REPORT
Surprise Valley Electrification Corp.
Reporting Period: July 1, 2018 – June 30, 2019

Type of Inspections (1)	July 1, 2018 – June 30, 2019	July 1, 2014 – June 30, 2019	Outstanding (3)
	Completed (2)	Previous 5 Years	
Patrols	100%	100%	0%
OH Detailed	19%	62%	0%
UG Detailed	0%	100%	0%
Wood Pole Intrusive	0%	0%	0%

*Percentages are based on total number of circuits on SVEC's California system.

Patrols

Beginning on March 27, 2019 and finishing on April 20, 2019, SVEC patrolled all overhead and underground structures and equipment while connecting irrigation pumps for the season.

OH Detailed

SVEC completed detailed inspections for all circuits on our Bieber Substation, Davis Creek Substation, and our Lookout Substation.

UG Detailed

SVEC has no detailed inspections to report at this time.

Wood Pole Intrusive

SVEC tested 111 poles on our 69kV transmission line beginning at the Austin Substation South to our Likely & Brockman Substations. This would be 21% of SVEC's entire 69kV transmission system in California.