

PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3298



January 12, 2015

Fred Mason
Electric Utility Director
City of Banning
176 E Lincoln Street
Banning, CA 92220

CPUCID: EA2014-026

SUBJECT: Electric Audit of City of Banning

Dear Mr. Mason:

On behalf of the Electric Safety and Reliability Branch of the California Public Utilities Commission, Derek Fong of my staff conducted an audit of City of Banning from September 29, 2014 to October 3, 2014. The audit included a review of City of Banning's records and field inspections of City of Banning's facilities.

During the audit, my staff identified violations of one or more General Orders (GOs). A copy of the audit findings itemizing the violations is enclosed. Please advise me no later than February 16, 2015, by electronic or hard copy, of all corrective measures taken by City of Banning to remedy and prevent such violations.

If you have any questions, you can contact Derek Fong at (213) 576-6850 or derek.fong@cpuc.ca.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Fadi Daye".

Fadi Daye, P.E.
Program and Project Supervisor
Electric Safety and Reliability Branch
Safety and Enforcement Division

Enclosure: Audit Findings

Cc: Elizaveta Malashenko, Deputy Director, Safety and Enforcement Division, CPUC
Charlotte TerKeurst, Program Manager, Electric Safety and Reliability Branch, CPUC

AUDIT FINDINGS

Location:	City of Banning
Date of CPUC Inspection:	09/29/2014
Explanation of Violation(s):	
<u>Late Detailed Inspections</u>	
<p>GO 95, Rule 31.1: Design, Construction, and Maintenance, States in part:</p> <p style="padding-left: 40px;"><i>Electrical supply and communication systems shall be designed, constructed, and maintained for their intended use, regard being given to the conditions under which they are to be operated, to enable the furnishing of safe, proper, and adequate service.</i></p> <p>GO 165, Section III-B: Standards for Inspection, States in part:</p> <p style="padding-left: 40px;"><i>Each utility subject to this General Order shall conduct inspections of its distribution facilities, as necessary, to ensure reliable, high-quality, and safe operation, but in no case may the period between inspections (measured in years) exceed the time specified in Table 1.</i></p> <p>City of Banning's records show that it detail-inspected the following number of poles: 1) 129 poles in the year 2014, 2) 150 poles in the year 2013, 3) 67 poles in the year 2012. Given that City of Banning has 4000 poles, the records reflect that the poles are not being detail-inspected on a five year cycle per GO 165, Section III-B.</p> <p><u>Missing Patrol Records</u></p> <p>GO 165, Section III-C: Record Keeping, States in part:</p> <p style="padding-left: 40px;"><i>For all inspections records shall specify the circuit, area, facility or equipment inspected, the inspector, the date of the inspection, and any problems (or items requiring corrective action) identified during each inspection, as well as the scheduled date of corrective action.</i></p> <p>City of Banning did not have any patrol records. City of Banning did not have any wood pole intrusive test records.</p>	

Lines not Inspected Frequently and Thoroughly

GO 95, Rule 31.2: Inspection of Lines, States in part:

Lines shall be inspected frequently and thoroughly for the purpose of insuring that they are in good condition so as to conform with these rules. Lines temporarily out of service shall be inspected and maintained in such condition as not to create a hazard.

During its detailed-inspections, City of Banning inspectors did not note any GO 95 nonconformances on the Inspection Log. City of Banning inspectors took an inventory of the facilities on the pole, but did not note the condition of the facilities on the pole.

The following violations were identified during the field inspection of the audit and were not documented and/or addressed by City of Banning during its last detailed inspection as required by General Order 165:

1.	Location:	Pole No. 3471
	Previous City of Banning Visit Details:	2/10/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p><u>Communication Cable in the Climbing Space</u></p> <p>GO 95, Rule 18-A1c: Resolution of Safety Hazards and GO 95 Nonconformances, States:</p> <p><i>Where a communications company's or an electric utility' actions result in GO nonconformances for another entity, that entity's remedial action will be to transmit a single documented notice of identified nonconformances to the communications company or electric utility for compliance.</i></p> <p>A communications cable was installed in the climbing space. City of Banning did not notify the communications company of this GO nonconformance when it last inspected the pole.</p> <p><u>Damaged Ground Molding</u></p> <p>GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p>The pole had damaged ground molding.</p>		

2.	Location:	Pole No. 3473
	Previous City of Banning Visit Details:	2/10/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, states in part:		
<p style="text-align: center;"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p>		
The high voltage sign on the crossarm was damaged.		

3.	Location:	Pole No. 3469
	Previous City of Banning Visit Details:	9/9/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Communication Cable in the Climbing Space</u>		
GO 95, Rule 18-A1c: Resolution of Safety Hazards and GO 95 Nonconformances, States:		
<p style="text-align: center;"><i>Where a communications company's or an electric utility' actions result in GO nonconformances for another entity, that entity's remedial action will be to transmit a single documented notice of identified nonconformances to the communications company or electric utility for compliance.</i></p>		
A communications cable was installed in the climbing space. City of Banning did not notify the communications company of this GO nonconformance when it last inspected the pole.		

4.	Location:	Pole No. 2625
	Previous City of Banning Visit Details:	9/15/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="162 514 568 556"><u>Damaged High Voltage Sign</u></p> <p data-bbox="162 588 941 630">GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p data-bbox="292 661 1347 745"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p data-bbox="162 777 844 819">The high voltage sign on the crossarm was damaged.</p> <p data-bbox="162 850 487 892"><u>Loose Down Guy Wire</u></p> <p data-bbox="162 924 1104 966">GO 95, Rule 56.2: Overhead Guys, Anchor Guys and Span Wires, States:</p> <p data-bbox="292 997 1315 1123"><i>Guys shall be attached to structures, as nearly as practicable, at the center of load. They shall be maintained taut and of such strength as to meet the safety factors of Rule 44.</i></p> <p data-bbox="162 1155 860 1197">The pole supported a down guy wire that was not taut.</p> <p data-bbox="162 1228 470 1270"><u>Missing Guy Marker</u></p> <p data-bbox="162 1302 682 1344">GO 95, Rule 56.9: Guy Marker, States:</p> <p data-bbox="292 1375 1347 1533"><i>A substantial marker of suitable material, including but not limited to metal or plastic, not less than 8 feet in length, shall be securely attached to all anchor guys. Where more than one guy is attached to an anchor rod, only the outermost guy is required to have a marker.</i></p> <p data-bbox="162 1564 747 1606">A down guy wire was missing a guy marker.</p>		

5.	Location:	Pole No. 4127
	Previous City of Banning Visit Details:	8/4/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Pole Step Too Low to the Ground</u>		
GO 95, Rule 51.7: Stepping, States:		
<p><i>The lowest step on any stepped pole, tower or structure shall be not less than 7 feet 6 inches from the ground line and above this point the spacing between steps on the same side of pole, tower or structure shall not exceed 36 inches.</i></p>		
The lowest pole step was approximately 5 feet above the ground line.		

6.	Location:	Pole No. 4322
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<p><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p>		
The high voltage sign on the crossarm was damaged.		

7.	Location:	Pole No. 6183
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Communication Cable in the Climbing Space</u>		
GO 95, Rule 18-A1c: Resolution of Safety Hazards and GO 95 Nonconformances, States:		
<p><i>Where a communications company's or an electric utility' actions result in GO nonconformances for another entity, that entity's remedial action will be to transmit a single documented notice of identified nonconformances to the communications company or electric utility for compliance.</i></p>		
A communications cable was installed in the climbing space.		

8.	Location:	Pole No. 4326
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<p><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p>		
The high voltage sign on the crossarm was damaged.		

9.	Location:	Pole No. 4973
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="175 520 560 552"><u>Damaged High Voltage Sign</u></p> <p data-bbox="175 594 933 625">GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p data-bbox="305 667 1347 741"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p data-bbox="175 783 795 814">The “voltage” sign on the crossarm was missing.</p> <p data-bbox="175 856 544 888"><u>Damaged Ground Molding</u></p> <p data-bbox="175 930 820 961">GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p data-bbox="305 1003 1339 1119"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p data-bbox="175 1161 690 1192">The pole had damaged ground molding.</p>		

10.	Location:	Pole No. 4972
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p><u>Damaged High Voltage Sign</u></p> <p>GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p style="text-align: center;"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p>The “voltage” sign on the crossarm was missing.</p> <p><u>Damaged Ground Molding</u></p> <p>GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p style="text-align: center;"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p>The pole had damaged ground molding at the public level.</p>		

11.	Location:	Pole No. 4970
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Missing Guy Marker</u>		
GO 95, Rule 56.9: Guy Marker, States:		
<p style="text-align: center;"><i>A substantial marker of suitable material, including but not limited to metal or plastic, not less than 8 feet in length, shall be securely attached to all anchor guys. Where more than one guy is attached to an anchor rod, only the outermost guy is required to have a marker.</i></p>		
A down guy wire was missing a guy marker.		

12.	Location:	Pole No. 4976
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<p style="text-align: center;"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p>		
The High Voltage sign on the crossarm was damaged.		

13.	Location:	Pole No. 6138
	Previous City of Banning Visit Details:	6/12/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="191 527 505 562"><u>Loose Down Guy Wire</u></p> <p data-bbox="191 604 1130 640">GO 95, Rule 56.2: Overhead Guys, Anchor Guys and Span Wires, States:</p> <p data-bbox="321 678 1325 789"><i>Guys shall be attached to structures, as nearly as practicable, at the center of load. They shall be maintained taut and of such strength as to meet the safety factors of Rule 44.</i></p> <p data-bbox="191 831 883 867">The pole supported a down guy wire that was not taut.</p> <p data-bbox="191 905 480 940"><u>Missing Guy Marker</u></p> <p data-bbox="191 978 691 1014">GO 95, Rule 56.9: Guy Marker, States:</p> <p data-bbox="321 1052 1357 1205"><i>A substantial marker of suitable material, including but not limited to metal or plastic, not less than 8 feet in length, shall be securely attached to all anchor guys. Where more than one guy is attached to an anchor rod, only the outermost guy is required to have a marker.</i></p> <p data-bbox="191 1243 761 1278">A down guy wire was missing a guy marker.</p>		

14.	Location:	Pole No. 6302
	Previous City of Banning Visit Details:	6/12/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Molding</u>		
GO 95, Rule 54.6-B: Ground Wires, states in part:		
<p style="text-align: center;"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p>		
The pole had damaged ground molding at the public level.		

15.	Location:	Pole No. 4983
	Previous City of Banning Visit Details:	6/12/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<p style="text-align: center;"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p>		
The “voltage” sign on the crossarm was missing.		

16.	Location:	Pole No. 4984
	Previous City of Banning Visit Details:	5/8/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="191 527 578 558"><u>Damaged High Voltage Sign</u></p> <p data-bbox="191 600 948 632">GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p data-bbox="321 674 1365 747"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p data-bbox="191 789 862 821">The High Voltage sign on the crossarm was missing.</p> <p data-bbox="191 863 545 894"><u>Abandoned Ground Wire</u></p> <p data-bbox="191 936 850 968">GO 95, Rule 31.6: Abandoned Lines, States in part:</p> <p data-bbox="305 1010 1365 1188"><i>Lines or portions of lines permanently abandoned shall be removed by their owners so that such lines shall not become a public nuisance or a hazard to life or property. For the purposes of this rule, lines that are permanently abandoned shall be defined as those lines that are determined by their owner to have no foreseeable future use.</i></p> <p data-bbox="191 1241 980 1272">The pole had an abandoned ground wire and ground molding.</p>		

17.	Location:	Pole No. 4985
	Previous City of Banning Visit Details:	5/8/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Missing High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i>		
The High Voltage sign on the crossarm was missing.		

18.	Location:	Pole No. 4988
	Previous City of Banning Visit Details:	5/8/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Molding</u>		
GO 95, Rule 54.6-B: Ground Wires, states in part:		
<i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i>		
The pole had damaged ground molding.		

19.	Location:	Pole No. 4989
	Previous City of Banning Visit Details:	5/8/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Missing High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i>		
The High Voltage sign on the crossarm was missing.		

20.	Location:	Pole No. 4354
	Previous City of Banning Visit Details:	2/26/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Molding</u>		
GO 95, Rule 54.6-B: Ground Wires, states in part:		
<i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i>		
The pole had damaged ground molding (there were two exposed ground wires at the public level).		

21.	Location:	Pole No. 6006
	Previous City of Banning Visit Details:	2/26/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Molding</u>		
<p>GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p style="text-align: center;"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p>The pole had damaged ground molding.</p>		

22.	Location:	Pole No. 4149
	Previous City of Banning Visit Details:	2/26/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Broken Transformer Secondary Neutral Ground</u>		
<p>GO 95, Rule 58.2-A1: Grounding of Windings, States in part:</p> <p style="text-align: center;"><i>Transformer windings, providing service not exceeding 300 volts (except those used exclusively for energizing street lighting systems or used exclusively for energizing signal and traffic circuits) shall be effectively grounded.</i></p> <p>The pole had a broken secondary ground wire for the transformer neutral (floating neutral).</p>		

22.	Location:	Pole No. 3051
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i>		
The High Voltage sign on the crossarm was damaged.		

23.	Location:	Pole No. 3052
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Molding</u>		
GO 95, Rule 54.6-B: Ground Wires, states in part:		
<i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i>		
The pole had damaged ground molding.		

24.	Location:	Pole No. 1614
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="186 527 553 562"><u>Missing High Voltage Sign</u></p> <p data-bbox="186 600 948 636">GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p data-bbox="321 674 1365 751"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p data-bbox="186 789 862 825">The High Voltage sign on the crossarm was missing.</p> <p data-bbox="186 863 505 898"><u>Loose Down Guy Wire</u></p> <p data-bbox="186 936 1130 972">GO 95, Rule 56.2: Overhead Guys, Anchor Guys and Span Wires, States:</p> <p data-bbox="321 1010 1325 1129"><i>Guys shall be attached to structures, as nearly as practicable, at the center of load. They shall be maintained taut and of such strength as to meet the safety factors of Rule 44.</i></p> <p data-bbox="186 1167 883 1203">The pole supported a down guy wire that was not taut.</p>		

25.	Location:	Pole No. 2332
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="188 522 574 554"><u>Damaged High Voltage Sign</u></p> <p data-bbox="188 596 946 630">GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p data-bbox="321 672 1360 743"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p data-bbox="188 785 878 819">The High Voltage sign on the crossarm was damaged.</p> <p data-bbox="188 861 558 892"><u>Damaged Ground Molding</u></p> <p data-bbox="188 934 833 968">GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p data-bbox="321 1010 1349 1121"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p data-bbox="188 1163 699 1197">The pole had damaged ground molding.</p>		

26.	Location:	Pole No. 2333
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="191 516 557 554"><u>Missing High Voltage Sign</u></p> <p data-bbox="191 594 948 632">GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p data-bbox="321 667 1365 743"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p data-bbox="191 783 862 821">The High Voltage sign on the crossarm was missing.</p> <p data-bbox="191 856 561 894"><u>Damaged Ground Molding</u></p> <p data-bbox="191 934 834 972">GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p data-bbox="321 1008 1354 1121"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p data-bbox="191 1161 699 1199">The pole had damaged ground molding.</p>		

27.	Location:	Pole No. 3662
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Wire</u>		
GO 95, Rule 33.3-A: Effective Grounds, States in part:		
<i>Supply equipment of the following types, when grounded to conform to requirements of this Order or for any other reasons, shall be effectively grounded.</i>		
The pole had a damaged ground wire (the wire was cut).		

28.	Location:	Pole No. 3663
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Wire</u>		
GO 95, Rule 33.3-A: Effective Grounds, States in part:		
<i>Supply equipment of the following types, when grounded to conform to requirements of this Order or for any other reasons, shall be effectively grounded.</i>		
The pole had a damaged ground wire (the wire was cut).		

29.	Location:	Pole No. 3664
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p><u>Damaged Ground Molding</u></p> <p>GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p style="text-align: center;"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p>The pole had damaged ground molding.</p>		

30.	Location:	Pole No. 6378
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p><u>Damaged Ground Molding</u></p> <p>GO 95, Rule 54.6-B: Ground Wires, states in part:</p> <p style="text-align: center;"><i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i></p> <p>The pole had damaged ground molding at the public level.</p>		

31.	Location:	Pole No. 3667
	Previous City of Banning Visit Details:	9/15/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Sign</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part: <i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i>		
The High Voltage sign on the crossarm was damaged.		

32.	Location:	Pole No. 6379
	Previous City of Banning Visit Details:	9/18/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Molding</u>		
GO 95, Rule 54.6-B: Ground Wires, states in part: <i>That portion of the ground wire attached on the face or back of wood crossarms or on the surface of wood poles and structures shall be covered by a suitable protective covering (see Rule 22.8).</i>		
The pole had damaged ground molding at the public level.		

33.	Location:	Pole No. 3672
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="186 527 574 558"><u>Damaged High Voltage Sign</u></p> <p data-bbox="186 600 946 632">GO 95, Rule 51.6-A: High Voltage Marking, States in part:</p> <p data-bbox="318 674 1360 747"><i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i></p> <p data-bbox="186 789 878 821">The High Voltage sign on the crossarm was damaged.</p> <p data-bbox="186 863 472 894"><u>Loose Conduit Strap</u></p> <p data-bbox="186 936 1130 968">GO 95, Rule 31.1: Design, Construction, and Maintenance, States in part:</p> <p data-bbox="305 1010 1352 1157"><i>Electrical supply and communication systems shall be designed, constructed, and maintained for their intended use, regard being given to the conditions under which they are to be operated, to enable the furnishing of safe, proper, and adequate service.</i></p> <p data-bbox="186 1199 634 1230">The pole had a loose conduit strap.</p>		

34.	Location:	Pole No. 3673
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged Ground Wire</u>		
GO 95, Rule 33.3-A: Effective Grounds, States in part:		
<i>Supply equipment of the following types, when grounded to conform to requirements of this Order or for any other reasons, shall be effectively grounded.</i>		
The pole had a damaged ground wire (the wire was cut).		

35.	Location:	Pole No. 3675
	Previous City of Banning Visit Details:	9/15/2014
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<u>Damaged High Voltage Wire</u>		
GO 95, Rule 51.6-A: High Voltage Marking, States in part:		
<i>Poles which support line conductors of more than 750 volts shall be marked with high voltage signs.</i>		
The "High" sign on the crossarm was damaged.		

36.	Location:	Pole No. 3674
	Previous City of Banning Visit Details:	None
	Date of CPUC Inspection:	9/29/2014
Explanation of Violation(s):		
<p data-bbox="191 522 1442 558"><u>Insufficient Clearance between City of Banning Service Drop and a Communications Cable</u></p> <p data-bbox="191 598 1230 634">GO 95, Rule 38: Minimum Clearances of Wires from Other Wires, States in part:</p> <p data-bbox="321 674 1425 747"><i>The minimum vertical, horizontal or radial clearances of wires from other wires shall not be less than the values given in Table 2 ...</i></p> <p data-bbox="191 787 1295 856">A City of Banning triplex service drop and a communications cable had a clearance of approximately 4 inches.</p>		