Operator ID#: 15007

# CITATION FOR VIOLATION(S) ISSUED PURSUANT TO RESOLUTION ALJ-274 OF GENERAL ORDER 112-E

Gas Corporation (Operator): Pacific Gas & Electric Company
To Which Citation Is Issued

#### **RESPONDENT:**

Mr. Jesus Soto, Vice President Pacific Gas & Electric Company 6111 Bollinger Canyon Road, Room 4590-D San Ramon, CA 94583

#### **CITATION:**

Operator is hereby cited for one violation resulting in a financial penalty of \$50,000.

#### **VIOLATION:**

Operator is cited with having violated General Order 112-E, as described below. The violation was discovered during the Meridian District audit conducted in 2012.

#### 49 CFR §192.201

- "(a) Each pressure relief station or pressure limiting station or group of those stations installed to protect a pipeline must have enough capacity, and must be set to operate, to insure the following:
  - (2) In pipelines other than a low pressure distribution system:
    - (i) If the maximum allowable operating pressure is 60 p.s.i. (414 kPa) gage or more, the pressure may not exceed the maximum allowable operating pressure plus 10 percent or the pressure that produces a hoop stress of 75 percent of SMYS, whichever is lower,"

The District's Self-Contained Relief Valve Maintenance Record, TD-4430-02-F06, for Durham Field, L-136, states an MAOP of 550 psig. The District set its relief valve protecting the system at 800 psig for two weeks from 10/15/12 to 11/1/12. The District

00 440 F OIT (00/0040)



### Public Utilities Commission

STATE OF CALIFORNIA

**Citation Date:** January 30, 2015 **Citation #:** ALJ 274 15-01-006

Operator ID#: 15007

did not set to operate its relief valve within the allowable limit established by Title 49, CFR §192.201.

Operator ID#: 15007

#### **ENCLOSURES:**

The following enclosures were used to establish the findings of fact:

1. Enclosure 1 - SED Investigation Report, 12/19/2014

- 2. Enclosure 2 SED PG&E GO 112-E Meridian District Audit Report, dated 8/02/2013
- 3. Enclosure 3 PG&E Response to GO 112-E Meridian District Audit Report, dated 10/14/2013

#### **STATEMENT OF FACTS:**

The above violation is documented in the attached *Enclosure 1 – SED Investigation Report* which is based on one or more of the following: Safety and Enforcement Division (SED) review of the 2013 PG&E GO 112-E Meridian District Audit, PG&E's response to the audit findings, Operator's records and/or substantiating documents obtained from other sources, or other reasons as stated in the attached report.



## Public Utilities Commission STATE OF CALIFORNIA

**Citation Date:** January 30, 2015 **Citation #:** ALJ 274 15-01-006

**Operator ID#:** 15007

#### **SED CITATION ANALYSIS**

Element of Sentencing Schedule	Staff Finding
Number of violation (s) and duration of	One violation of Title 49 CFR §192.201
violation (s) since inception	from 10/15/12 to 11/1/12
Severity of the offense: overall level of risk	One violation resulting in total fine amount
of violation(s)	of \$50,000
The conduct of the utility before, during,	The utility is being cooperative and has
and after the offense	undertaken corrective actions
Previous occurrence of similar violations	N/A
by the utility	
Self-reporting of the violation	Not self-reported. Violation found as a
	result of GSRB 2013 PG&E GO 112-E
	Meridian District Audit
Indication of the violation (s) being willful	No
Actions taken by the utility to address the violation	Refer to Enclosures 1 thru 3
Associated safety related condition	N/A
Financial resources of the utility	4.3 Million customers, \$715 Million
	Revenue requirement
The totality of the circumstances	The relief valve protecting a 550 psig
	MAOP line was set to relieve at 800 psig -
	49CFR192.201; The violation affects
	PG&E's local transmission system.
Other factors deemed relevant by SED	The utility has taken corrective actions.
Resultant Citation Taking All Of These	\$50,000.00
Factors Into Account	

Operator ID#: 15007

#### **RESPONSE:**

Respondent is hereby called upon to provide a response to this Citation by: 5:00 PM (PST) on February 9, 2015.

By way of such response, Respondent, within 10 calendar days, may either:

- (1) Correct the violations with any immediate safety hazard requiring immediate correction as soon as feasible, and/or submit a Compliance Plan to the Director of SED for correcting those violations requiring more than 10 days to correct, and pay a fine pursuant to Pub. Util. Code § 2107. (Submit a check payable to California Public Utilities Commission using the attached Citation Payment Form. Upon payment, the fine will be deposited in the State Treasury to the credit of the General Fund and this citation will become final); or
- (2) Confirm that the violation(s) noted in this Citation have been corrected and/or otherwise do not present an on-going safety hazard to the Operator's employees and the general public, and/or submit a Compliance Plan to the Director of SED for correcting those violations requiring more than 10 days to correct, **and** contest this citation by completing and submitting a *Notice of Appeal Form*. Please see the attached document, "Directions For Submitting An Appeal To A Citation Issued Pursuant To Resolution ALJ-274" for information on the appeals process and the attached "Notice of Appeal Form. Also attached is a copy of Resolution ALJ-299 including Appendices A and B.

Respondent's failure to provide a response, as noted above, within 10 calendar days from the date the citation is served, will place Respondent in default of the citation and will result in forfeiture of Respondent's rights to appeal the citation. A late payment will be subject to a penalty of 10% per year, compounded daily and to be assessed beginning the calendar day following the payment-due date. The Commission may take additional action to recover any unpaid fine and ensure compliance with applicable statutes and Commission orders.

#### **NOTIFICATION TO PUBLIC AGENCIES:**

As soon as is reasonable and necessary, and <u>no later than 10 calendar days</u> after service of the citation is effected, Respondent must provide a notification to the City Manager or similar local agency authority in the city and county where a citation is issued. <u>Within 10 days of providing such notification</u>, Respondent must serve an affidavit to the Director of SED, at the mail or e-mail address noted below, attesting that the local authorities have been notified; the date(s) for when notification was provided; and the name(s) and contact information for each local authority so notified.

Operator ID#: 15007

The CPUC expects Operators to take actions, as soon as feasible, to correct, mitigate, or otherwise make safe all violations noted on the Citation regardless of the Operator's intentions to accept or appeal the violation(s) noted in the Citation.

Elizaveta Malashenko

Deputy Director
Office of Utility Safety and Reliability
Safety and Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102
elizaveta.malashenko@cpuc.ca.gov

Operator ID#: 15007

#### **CITATION PAYMENT FORM**

I (we)	hereby agree to comply with this citation		
dated	, and have corrected/mitigated the violation(s)		
noted in the citation on	n and no later than,		
all work to make permanent cor	rections to any mitigated, or o	otherwise remaining	
concerns related to the violation	n(s) will be completed as note	d in the Compliance Plan	
we have submitted to the Direct	or of SED and, herewith, pay	a fine in the amount of \$	
as includ	ded in the citation.		
	Signature of Gas Co hief Financial Officer, o elegated Officer thereof		
	(Signature)	(Date)	
	(Printed Name a	and Title)	

Payment with a check must be made payable to the *California Public Utilities*Commission and sent to the below address. Please include the citation number on the memorandum line of the check to ensure your payment is properly applied.

California Public Utilities Commission Attn: Fiscal Office 505 Van Ness Avenue San Francisco, CA 94102-3298

NOTE: A copy of the completed Citation Payment Form must be sent to the Director of the Safety and Enforcement Division, via email or regular mail, to the addresses provided on the Citation.

00 440 E 0IT /00/0040



0------

Operator ID#: 15007

### DIRECTIONS FOR SUBMITTING AN APPEAL TO A CITATION ISSUED PURSUANT TO RESOLUTION ALJ-274

Within 10 calendar days of the Respondent being served with a <u>CITATION FOR VIOLATION(S) ISSUED PURSUANT TO RESOLUTION ALJ-274</u>, Respondent may appeal the citation. Beyond 10 calendar days of being served with the citation, Respondent is in default and, as a result, is considered as having forfeited rights to appeal the citation. The Respondent must still correct the violation(s) as feasible unless, within 10 calendar days from the date of service of the citation, the Respondent submits to the Director of SED, a Compliance Plan that provides a detailed description of when the violation(s) will be corrected, the methodology to be utilized, and a statement, supported by an affidavit from the Gas Corporation's Chief Executive Officer, that in the Respondent's best judgment, the time necessary to correct the violation(s) will not affect the integrity of the operating system or unduly endanger the public.

To appeal the citation, Appellant must file a Notice of Appeal (including a completed title page complying with Rule 1.6 of the Commission's Rules of Practice and Procedure, and attached Notice of Appeal Form) along with copies of any materials the Appellant wants to provide in support of its appeal with the Commission's Docket Office **and** must be served, at a minimum, on

- 1) The Chief Administrative Law Judge (with an electronic copy to: ALJ Div Appeals Coordinator@cpuc.ca.gov),
- 2) The Director of Safety and Enforcement Division
- 3) The Executive Director
- 4) General Counsel
- 5) The Director of the Division of Ratepayer Advocates

within 10 calendar days of the date on which the Appellant is served the Citation at the address listed below. The Appellant must file a proof of service to this effect at the same time the Appellant files the Notice of Appeal. The Notice of Appeal must at a minimum state: (a) the date of the citation that is appealed; and (b) the rationale for the appeal with specificity on all grounds for the appeal of the citation.

California Public Utilities Commission 505 Van Ness Ave, San Francisco, CA 94102 Attn: <Insert Title>

**NOTE:** Submission of a *Notice of Appeal Form* in no way diminishes Appellant's responsibility for correcting the violation described in the citation, or otherwise ensuring the safety of facilities or conditions that underlie the violations noted in the Citation.



### Public Utilities Commission STATE OF CALIFORNIA

**Citation Date:** January 30, 2015 **Citation #:** ALJ 274 15-01-006

Operator ID#: 15007

Ex Parte Communications as defined by Rule 8.1(c) of the Commission's Rules of Practice and Procedure, are prohibited from the date the citation is issued through the date a final order is issued on the citation appeal.

After SED receives the Appellant's *Notice of Appeal Form*, a hearing will be convened before an Administrative Law Judge. At least ten business days before the date of the hearing, the Appellant will be notified and provided with the location, date, and time for the hearing. At the hearing,

- (a) Appellant may be represented by an attorney or other representative, but any such representation shall be at the sole expense of the Respondent;
- (b) Appellant may request a transcript of the hearing, but must pay for the cost of the transcript in accordance with the Commission's usual procedures;
- (c) Appellant is entitled to the services of an interpreter at the Commission's expense upon written request to the Chief Administrative Law Judge not less than five business days prior to the date of the hearing; and
- (d) Appellant may bring documents to offer in evidence (Rule 13.6 (Evidence) of the Commission's Rules of Practice and Procedure applies) and/or call witnesses to testify on Respondent's behalf. At the Commission's discretion, the hearing in regard to the Appellant's appeal can be held in a hearing room at either of the offices of the CPUC at the following locations:

San Francisco:

505 Van Ness Avenue San Francisco, CA 94102 Los Angeles:

320 West 4<sup>th</sup> Street, Suite 500 Los Angeles, CA 90013

The hearing(s) held in regard to the Appellant's appeal will be adjudicated in conformance with all applicable Public Utilities Code requirements.



Operator ID#: 15007

## Notice of Appeal Form Appeal of PG&E from Citation ALJ 274 15-01-006 issued by Safety and Enforcement Division (For A Citation Issued Pursuant to Resolution ALJ-274)

### Appellant:

Name Vice President, Gas Operations Gas Utility Name Mailing Address City, CA Zip

Citation Date:	
Citation #:	
Operator ID#:	
Appeal Date:	

"Appeal of [insert Operator Name] from [insert Citation number] issued by Safety and Enforcement Division"

Statements supporting Appellant's Appeal of Citation (You may use additional pages if needed and/or attach copies of supporting materials along with this form).



## Public Utilities Commission STATE OF CALIFORNIA

**Citation Date:** January 30, 2015 **Citation #:** ALJ 274 15-01-006

Operator ID#: 15007

#### **Enclosures to Accompany Utility Appeal**

Utility to add Enclosures as appropriate